



# Secure Power Switch Master/Satellite 8-Port



## System Administrator's Guide





This product carries the CE mark to indicate compliance with the European Directive on Electromagnetic Compatibility (89/336/EEC). It has been tested to EN55024:1998 and EN55022:1998.

## PSE518 MA/SA

**Secure Power Switch PSE518 MA** (the Master) and **PSE518 SA** (the Satellite) are a couple of power control units that enable remotely power control with the highest security over Intranet or Internet.

Secure Power Switch PSE518 MA (the Master) is a power control unit with a built-in Web server, an Ethernet and a RS232 connection. It enables to control the power supply of 8 Power Outlets through an Ethernet connection. The number of controlled Power Outlets can be extended up to 136 by cascading up to 16 Power Switch Satellite to the PSE518 MA (Master). It supports a maximum load of 2x10A through 2 separate power inputs.

This high security unit offers HTTPS protocol with Web browsers that support SSL version 2 or 3.

It also supports plenty of control options, like IP devices monitoring, external temperature/humidity sensors and dry contacts. It is able to send Syslog information and e-mails, and to record all events into a time-stamped log file.

Secure Power Switch Satellite is a power control unit with a serial connection. It enables to control the power supply of 8 Power Outlets either through a serial RS232 or RS485 connection. The number of the controlled Power Outlets can be extended up to 128 by cascading up to 16 Power Switch Satellite.

Like the Master, this unit has two separate power inputs to increase the security and the load available on the power outlets.



# Contents

## Chapters

1. Safety instructions: to read before use!	3
2. Package list	5
2.1 Power Switch units	5
2.2 Power Switch accessories (must be ordered separately)	5
3. Diagram	6
3.1 The Front Panel of the Power Switch Master	6
3.2 The Back Panel of the Power Switch Master	8
3.3 The Front Panel of the Power Switch Satellite	9
3.4 The Back Panel of the Power Switch Satellite	10
4. Installation the Power Switch Master	11
5. Configuring the Power Switch Master	12
5.1 Configuring the network settings of the Power Switch Master with the Finder Program	13
5.2 Configuring the network settings of the Power Switch Master through a Terminal connection	15
5.3 Configuring the network settings of the Power Switch Master with a browser	16
5.3.1 General / IP Configuration Page	17
5.3.2 General / System Time Page	18
5.3.3 General / SMTP Page	19
5.3.4 General / SNMP Page	20
5.3.5 General / Tools Page	21
5.3.6 Settings / Accounts Page	22
5.3.7 Settings / Groups Page	24
5.3.8 Settings / Power Outlets Page	25
5.3.9 Settings / Sensors Page	27
5.3.10 Settings / I/O	28
5.3.11 Settings / Rules Page	29
5.3.12 Ping Monitoring Rule	30
5.3.13 Scan Monitoring Rule	32
5.3.14 Dry Contact Monitoring Rule	34
5.3.15 Power Supply Monitoring Rule	36
5.3.16 Schedule Rule	38
5.3.17 Environment Rule	40
5.3.18 Misc / Peripherals page	42
5.3.19 Misc / I/O Status	43
5.3.20 Misc / Log page	44
5.3.21 Misc / Log Settings Page	45
6. Controlling the Power Outlets of the Master and Satellites	46
7. Installation the Power Switch Satellite	47
8. Controlling the Power Outlets of the Satellites using a Terminal Connection	48
8.1 Using the RS232 port	48
8.2 Using the RS485 port	48
8.3 Commands	48
8.3.1 Controlling of the Power Outlet(s)	49
8.3.2 Reading out the Power Outlet Status	50
8.3.3 Setting of the Power Up Delays	51
8.3.4 Reading out of the Power Up Delay(s)	51
8.3.5 Setting the Restart Delays	52
8.3.6 Reading out of the Restart Delays	52
8.3.7 Setting the Power Up Default Status	53
8.3.8 Reading out the Power Up Default Status	53
8.3.9 Reading out the Switching Counter Values of the Relays	54
8.3.10 Resetting the Switching Counter Values of the Relays	55
8.3.11 Restoring to Factory Settings	55
9. Accessories	56
9.1 Temperature sensor	56
9.2 Temperature and Humidity sensor	56
9.3 I/O extension module	57
9.4 Cable managing and vertical rack mouting kit	57
Annexes	58
Ping and Scan methods	58
Address Pinging	58
Port Scanning	58
Recommended values	58
Commonly used ports	58
SysLog Messages: Severity Level Definitions	59
Pinout of the RJ11 6/6 x-Bus connector	60
Technical Data	61

## Chapter Description

### Chapter 1 Safety Instructions

This chapter contains important safety instructions you should know before working with Power Switch Master and Satellite.

#### **IMPORTANT SAFETY INSTRUCTIONS TO BE READ**



This warning symbol means danger. You are in a situation that could cause bodily injury. Before you work on any Power Switch device:

- be aware of the hazards involved with electrical circuitry
- be familiar with the practices for preventing accidents

#### **SAVE THESE INSTRUCTIONS !**

### Chapter 2 Package list

This chapter introduces you to the Power Switch Master and Satellite Packing List. It also introduces the Power Switch accessories (temperature sensor, temperature/humidity sensor and the I/O Extension Board)

### Chapter 3 Diagram

This chapter describes the Front and Back Panel of the Power Switch Master and the Power Switch Satellite.

### Chapter 4 Installation the Power Switch Master

This chapter describes how to install the Power Switch Master.

### Chapter 5 Configuring the Power Switch Master

This chapter describes how to configure the Power Switch Master.

### Chapter 6 Controlling the Power Outlets

This chapter describes how to control the Power Outlets of the Master and the Satellite over IP.

### Chapter 7 Installation the Power Switch Satellite

This chapter describes how to install the Power Switch Satellite.

### Chapter 8 Controlling the Power Outlets of Power Switch Satellite using a terminal connection

This chapter describes how to control the Power Outlets of the Power Switch Satellite.

### Chapter 9 Accessories

This chapter describes the accessories, which can be connected to the Power Switch Master.

### Annexes Ping and Scan method

#### Commonly used ports

#### SysLog Messages: Severity Level Definitions

#### Pinout of the RJ11 6/6 x-Bus connector

#### Technical Data

# 1. Safety instructions: to read before use!



## NOTE

English

In the following instructions "Power Switch device" refers to both devices Power Switch Master and Power Switch Satellite.

- The Power Switch devices can only be installed by qualified people with the following installation and use instructions. The manufacturer disclaims all responsibility in case of a bad utilization of the Power Switch devices and particularly any use with equipments that may cause personal injury or material damage.
- This equipment is designed to be installed on a dedicated circuit that must have a circuit breaker or fuse protection.
- The electrical power sockets used to plug the power cords of the Power Switch devices must be close to the Power Switch devices and easily accessible.
- Check that the power cords, plugs and sockets are in good condition.
- The Power Switch devices can only be connected to three-wire 230 VAC (50-60Hz) sockets.
- Always plug the Power Switch devices into properly grounded power sockets (two poles plus ground).
- Never exceed 10 Amp total load for each group of 4 power outlets of an Power Switch device.
- The Power Switch devices are intended for indoor use only. Do NOT install them in an area where excessive moisture or heat is present.
- Always disconnect the 2 (two) power cords of the Power Switch device if you want to intervene on the Power Switch device or on the equipment powered from the Power Switch device.
- The Power Outlets of the Power Switch devices are not circuit breakers! If you want to intervene on equipments connected to an Power Switch device you must disconnect these equipments from the Power Switch device.
- Do NOT attempt to disassemble the Power Switch devices, they contain potentially hazardous voltages.
- The Power Switch devices contain no user serviceable parts and repairs are to be performed by factory trained service personnel only.
- Always use a shielded cable for the Ethernet connection.

# Consignes de sécurité : à lire avant utilisation !



## Remarque

# Français

Dans les consignes suivantes, "équipements Power Switch" fait référence aux deux produits Power Switch Master et Power Switch Satellite.

- Les équipements Power Switch ne peuvent être installés que par un personnel qualifié. Le fabricant décline toute responsabilité en cas de mauvaise utilisation des équipements Power Switch et tout particulièrement en cas d'utilisation avec des équipements pouvant occasionner des blessures corporelles ou des dommages matériels.
- Les équipements Power Switch sont destinés à être installés sur un ou plusieurs circuits électriques dédiés protégés par des disjoncteurs ou des fusibles.
- Les prises secteur utilisées pour brancher les cordons secteur d'alimentation des équipements Power Switch doivent être à proximité des équipements Power Switch et facilement accessibles.
- Vérifiez que les cordons secteur d'alimentation, les connecteurs et les prises secteur sont en bon état.
- Les équipements Power Switch ne peuvent être connectés qu'à une/des prise(s) secteur à 3 conducteurs (2 prises + terre) 230 VAC (50-60Hz).
- N'utilisez que des prises secteur correctement mises à la terre (deux prises + terre) pour brancher les câbles secteur des équipements Power Switch.
- Ne jamais dépasser un courant total de 10 Amp pour chaque entrée secteur des équipements Power Switch.
- Les équipements Power Switch sont destinés à une utilisation intérieure. NE les installez JAMAIS dans un endroit où règne une humidité ou une chaleur excessive.
- Débranchez TOUJOURS les 2 cordons secteur d'alimentation des équipements Power Switch si vous souhaitez intervenir sur les équipements Power Switch ou sur les appareils alimentés au travers des équipements Power Switch.
- Les prises secteur des équipements Power Switch ne sont PAS des coupe-circuits ! Si vous souhaitez intervenir sur les appareils alimentés au travers des équipements Power Switch vous devez IMPERATIVEMENT débrancher ces appareils des équipements Power Switch.
- Ne démontez JAMAIS le Power Switch, il y a risque de choc électrique !
- Les équipements Power Switch ne contiennent pas de pièces nécessitant une maintenance. Les éventuelles réparations ne peuvent être faites que par un personnel habilité et formé par le fabricant.
- Utilisez toujours un câble blindé pour la connexion Ethernet.

## 2. Package list

### 2.1 Power Switch units

#### Power Switch Master

The following items are included:

- 2 Power cables, 230 V/10 Amp, length: 1.80 m
- 1 power adapter 12 VDC for web server auxiliary power supply
- 1 serial cable SUB-D 9 points male/female, length: 1.80 m
- CD including this user guide and the Power Switch Finder program
- Quick Installation guide

#### Power Switch Satellite

The following items are included:

- 2 Power cables, 230 V/10 Amp, length: 1.80 m
- 1 xBus connection cable, length: 0.30 m
- 1 serial cable SUB-D 9 points male/female, length: 1.80 m
- CD including this user guide
- Quick Installation guide

### 2.2 Power Switch accessories (must be ordered separately)

#### Power Switch Temperature sensor

The following items are included:

- 1 xBus connection cable, length: 1.80 m
- Printed user guide

#### Power Switch Temperature and Humidity sensor

The following items are included:

- 1 x Bus connection cable, length: 1.80 m
- Printed user guide


#### Power Switch I/O Extension Board

The following items are included:

- 1 SUB D 25 M/M cable, length: 1.80 m
- Printed user guide

## 3. Diagram

### 3.1 The Front Panel of the Power Switch Master



#### A 1 2 3 4 (LEDs)

- A Green. Lights up when Power applied on Group A
- 1 Red. Status of Power Outlet 1 (On/Off)
- 2 Red. Status of Power Outlet 2 (On/Off)
- 3 Red. Status of Power Outlet 3 (On/Off)
- 4 Red. Status of Power Outlet 4 (On/Off)

#### 10/100 (RJ45 Connector)

Network connection 10/100 Mbits/sec

#### Link (LED)

Off = Network connection not detected

On = Network connection detected

Flashing = the device is sending or receiving data over this port

#### 100 (LED)

Off = 10 Mbits/sec connection

On = 100 Mbits/sec connection

#### RS232 (SUB-D 9F Connector)

Serial port RS232 with DB-9 female connector

Pinout

2 = TxD

3 = RxD

5 = Gnd



**xBus**

These connectors are used for cascading Power Switch devices together (up to 16 Power Switch Satellite and up to 16 Temperature / Humidity sensors).

Maximal TOTAL line length: 200 Meters

**Term (RS485 Termination DIP Switch)**

The xBus interface (RS485) has built-in termination resistors. To enable these resistors slide the two DIP Switch to the ON position (down).

Termination should be enabled at the two end stations on an RS485 network.

No more than two stations should be terminated on an RS485 network

**S B 5 6 7 8 1 2 3 4 (LEDs)****S** Status

On = Power Switch Master software is loaded and functional

Off = power default

1 time repeatedly = power on but not ready

2 times repeatedly = waiting on IP address from DHCP server

3 times repeatedly = SSL key computing in progress (takes several minutes!!!)

4 times repeatedly = System error (contact the manufacturer)

**B** Green. Lights up when Power applied on Group B**5** Red. Status of Power Outlet 5 (On/Off)**6** Red. Status of Power Outlet 6 (On/Off)**7** Red. Status of Power Outlet 7 (On/Off)**8** Red. Status of Power Outlet 8 (On/Off)**1** Yellow. Status of Dry contact Output 1 (Open/Closed)**2** Yellow. Status of Dry contact Output 2 (Open/Closed)**3** Yellow. Status of Dry contact Output 3 (Open/Closed)**4** Yellow. Status of Dry contact Output 4 (Open/Closed)**I/O (SUB-D 25F Connector)**

Dry Contacts: 4 Outputs and 8 Inputs

Do NOT exceed 24VDC – 20 mA

(see Annexe Table for the Pin configuration)

**12 VDC AUX Power Supply**

The Web server can be powered either by Power Input A or Power Input B.

To increase the operational safety of the Web server, an auxiliary Power Supply (12 VDC / 300 mA) can be connected to this input (double insulated, ie. not connected to ground).

### 3.2 The Back Panel of the Power Switch Master




**Power Outlets (Group B)**  
Power Outlets 5 – 8  
230 VAC max 10 Amp

**Power Input B**  
230 VAC – 10 Amp

**Power Outlets (Group A)**  
Power Outlets 1 – 4  
230 VAC max 10 Amp

**Power Input A**  
230 VAC – 10 Amp

### 3.3 The Front Panel of the Power Switch Satellite



#### A B 1 2 3 4 5 6 7 8 (LEDs)

- A Green. Lights up when Power applied on Group A
- B Green. Lights up when Power applied on Group B
- 1 Red. Status of Power Outlet 1 (On/Off)
- 2 Red. Status of Power Outlet 2 (On/Off)
- 3 Red. Status of Power Outlet 3 (On/Off)
- 4 Red. Status of Power Outlet 4 (On/Off)
- 5 Red. Status of Power Outlet 5 (On/Off)
- 6 Red. Status of Power Outlet 6 (On/Off)
- 7 Red. Status of Power Outlet 7 (On/Off)
- 8 Red. Status of Power Outlet 8 (On/Off)

#### Dip Switches

- 1 - 4: physical address of device
- 5 - 6: xBus Termination

#### RS232 (SUB-D 9F Connector)

- RS232 serial port with DB-9 female connector
- Pinout
- 2 = Rx D
- 3 = Tx D
- 5 = Gnd

#### xBus (RS485)

These connectors are used for cascading Power Switch devices together, up to 16 Power Switch Satellite and up to 16 Temperature / Humidity sensors.  
Maximal TOTAL line length: 200 meters

### 3.4 The Back Panel of the Power Switch Satellite



**Power Outlets (Group B)**  
Power Outlets 5 – 8  
230 VAC max 10 Amp

**Power Outlets (Group A)**  
Power Outlets 1 – 4  
230 VAC max 10 Amp

**Power Input B**  
230 VAC – 10 Amp

**Power Input A**  
230 VAC – 10 Amp

## 4. Installation the Power Switch Master

### Remark:

Make sure that the Power Switch Master is powered off.

### Connection Instructions

1. Use a shielded RJ45 Network Cable to connect your Power Switch Master to the network.
2. Use appropriated three-wire Power Cords (two poles plus ground) to connect your electrical devices to the Power Switch Master unit.
3. Plug the 2 power cables into 2 grounded sockets. The Power Supply LED of group A and of group B light on to confirm that power is on.
4. You can now configure the Power Switch Master by following the indications of the chapter "Configuration of the Power Switch Master" or, if necessary, install the Power Switch Satellite as indicated hereafter.

## 5. Configuring the Power Switch Master

To use the Power Switch Master on your network, you must first configure its network parameters. Ask your network administrator for the parameters to use.

**There are three different methods to configure the Power Switch Master:**

### Method 1:

Through a network using the Power Switch Finder Program (on the delivered CD).

It is the simplest and fastest configuration method if you use Windows as operating system. We suggest that you use this program at least during the first configuration: it allows you to configure your Power Switch Master through your local network even if its network parameters (IP Address, Subnet mask and Port) are not compatible with those of your PC or your local network.

If you decide to use this method you can directly go to chapter "Configuring the network settings of the Power Switch Master with the Finder Program".

### Method 2:

Through a network using a Web browser (Internet Explorer > 6.0 or Netscape > 6.1).

This method can only be used if the network parameters of the Power Switch Master (IP Address, Subnet mask...) have already been configured using either the Power Switch Finder program (Method 1) or using a Terminal program (Method 3).

For the first configuration you can also change the Network parameters of your PC according to the default settings of the Power Switch.

Default Network parameters:

<b>IP address</b>	192.168.100.200
<b>Subnet mask</b>	255.255.255.0
<b>Gateway</b>	no address
<b>Protocol</b>	https
<b>Port</b>	443 (https !!!)

If you decide to use this method you can directly go to the chapter "Configuring the network settings of the Power Switch Master with a browser".

### Method 3:

Through a RS232 serial connection using a Terminal connection.

If you use a PC, use the supplied serial cable and a Terminal program such as Windows HyperTerminal or the MicroTerminal program on the CD (folder miscellaneous).

If you decide to use this method, you can directly go to the chapter "Configuring the network settings of the Power Switch Master through a Terminal connection".

## 5.1 Configuring the network settings of the Power Switch Master with the Finder Program

### Remarks:


The Power Switch Master and the PC used to configure it, have to be connected on the same segment of the network. The protocol of this program can not be routed so it can not be used to configure the Power Switch through a WAN or the Internet.

This program does not work if the administrator has deactivated it in the configuration of the Power Switch Master (for security reasons for example).

1. Start the PS-Finder.exe program on the CD-ROM.  
The Power Switch Finder window appears.



2. In the tool bar click on the first left button or choose the **File/Scan Menu**. The program browses the segment on which is connected your PC and displays the name, the type, the IP and MAC Address of the connected Power Switch.
3. In the tool bar click on the second left button or choose the **File/Configure Menu**. The properties dialog box appears and you can now configure the network parameters.



This page enables to define all IP parameters of the Power Switch Master device and displays the version of the Firmware. The HTTPS Protocol is enabled and the Finder Program is authorized at factory settings.  
**!!! To achieve the highest security level, we suggest to disable the configuration using the Finder program after the first installation.**

**DHCP**

If this check box is selected, the web server will automatically initialise the IP address from a DHCP host and disable manual IP address setup. Note that use of DHCP (Dynamic Host Configuration Protocol) requires a DHCP host to be set up on the network.

**IP Address**

IP address of Power Switch Master, default is 192.168.100.200.

**Subnet Mask**

Subnet Mask of Power Switch Master, default is 255.255.255.0.

**Gateway**

Generally the address of your router, default is blank.

**DNS 1**

Primary DNS (Domain Name Server), default is blank.

**DNS 2**

Secondary DNS, default is blank.

**Version**

Firmware version of the Power Switch Master

**Finder authorized**

The Network parameters of the Secure Power Switch Master can also be configured through a Local Area Network using the provided Finder Program. It is a simple and fast configuration method if you use Windows as operating system.

**!!! The Finder Program is enabled as default value. For security reasons we suggest to disable the Finder program after the first configuration.**

**HTTP / HTTPS Access**

These options enable to choose between the standard HTTP and the HTTP over SSL protocol.

HTTPS encrypts and decrypts the page requests and page information between the client browser and the web server of the Power Switch Master using a Secure Socket Layer (SSL). HTTPS by default uses port 443 and HTTP the port 80. A URL beginning with HTTPS indicates that the connection is encrypted using SSL. SSL transactions are negotiated by means of a Key-based encryption algorithm between your browser and the web server of your Power Switch Master.

The HTTPS protocol is enabled as default value to achieve the highest security level.



## 5.2 Configuring the network settings of the Power Switch Master through a Terminal connection

### Remarks:

For security reasons, we advise you to disable the Finder program after the first installation. This program **does not** use SSL technology, it is only intended for a first quick installation over the LAN.

If you change the IP address, the system needs to compute new SSL keys. This operation takes several minutes and the LED marked "S" on the front panel blinks 3 times repeatedly during all the process. During all this time, you cannot login.

1. Use the supplied RS232 serial cable to connect the serial port marked RS232 on the front panel of the Power Switch Master to an available serial port of your PC.
2. Run a terminal program such as Windows HyperTerminal or the MicroTerminal program on the CD ("Miscellaneous" folder).
3. Configure the appropriate serial port with the following settings: 9.600 bauds, 8 bits, no parity, 1 stop bit and no flow control. If you use the MicroTerminal program on the supplied CD-ROM ("Miscellaneous" folder) you only have to choose the used serial port, this program is already configured at 9600,n,8,1.
4. On your computer, press <ENTER> until the configuration's menu appears on your screen, then press "M" and follow the menu to configure the network parameters of your Secure Power Switch Master.

The serial connection also enables you to use following commands.

/viewlog	Displays the log file
/initlog	Clears the log file
/initsslkey	Computes new SSL keys (needs several minutes!)
/initadminaccount	Restores default administrator password
/restorefactconf	Restores to factory default settings
/help	Displays this help
/?	Displays this help


## 5.3 Configuring the network settings of the Power Switch Master with a browser

### Remarks:


In order to be able to access the Web server of the Power Switch Master, you must before have configured its network parameters (ask your network administrator for the parameters to use).

The Web server of the Power Switch Master works with Internet Explorer Version 6.0 or higher and with Netscape Version 6.1 or higher.

1. Start your Web browser.
2. Type the IP address of your Power Switch Master following by /sysadmin.htm to access to the configuration page.  
Example: <http://192.168.1.180/sysadmin.htm>  
The browser displays the authentication dialog box.



3. Enter the administrator **name** and **password** then click on **OK** (default values = admin for name and password).  
The configuration page is displayed, allowing you to set all the parameters of the Power Switch Master. There are four main tabs: General, Settings, Misc and Help. Additional tabs will be available after you click one of the main tabs.



### 5.3.1 GENERAL / IP CONFIGURATION PAGE

This page enables you to define all the IP parameters of the Power Switch Master device (IP Address, Subnet Mask, Default Gateway, Primary and Secondary DNS Server).

The screenshot shows the 'IP Configuration' page of the 'Secure Power Switch' interface. The page has a navigation bar with 'General', 'Settings', 'Misc', and 'Help'. Below this is a sub-navigation bar with 'IP Configuration', 'System Time', 'SMTP', 'SNMP', and 'Tools'. The main content area is titled 'IP Configuration' and contains several configuration options. 'DHCP Client enabled' is a checkbox that is currently checked. Below it are input fields for 'IP Address' (192.168.1.251), 'Subnet Mask' (255.255.255.0), 'Default Gateway' (192.168.1.2), 'Primary DNS Server' (192.168.1.2), and 'Secondary DNS Server' (0.0.0.0). Further down, 'Finder Program enabled' is a checked checkbox. 'HTTPS Access' is a radio button, and 'HTTP Access' is a radio button. An 'HTTP Port' field is set to 80. At the bottom of the page are three buttons: 'LOGOUT', 'DISCARD CHANGES', and 'APPLY CHANGES'.

#### DHCP Client enabled

If this check box is selected, the web server will automatically initialize the IP address from a DHCP host and disable manual IP address setup. Factory default setting for this option is enabled.

!!! Use of DHCP (Dynamic Host Configuration Protocol) requires a DHCP host to be set up on the network.

#### IP Address

IP address of Power Switch Master, default is 192.168.100.200.

!!! If you change the IP address, the system needs to compute new SSL keys. This operation takes several minutes and the LED marked "S" on the front panel blinks 3 times repeatedly during all the process. During all this time, you cannot login.

#### Subnet Mask:

Subnet Mask of Power Switch, default is 255.255.255.0.

#### Default Gateway:

Generally the address of your router, default is blank

#### Primary DNS Address

Primary DNS (Domain Name Server), default is blank

#### Secondary DNS Address

Secondary DNS, default is blank

#### Finder Program enabled

The Network parameters of the Power Switch Master (IP address, Default Gateway...) can also be configured through a network using the provided Finder Program. It is the simplest and fastest configuration method if you use Windows as an operating system.

If you do not want to use the Finder Program, uncheck the box "Finder program enabled".

#### HTTP / HTTPS Access

These options enable to choose between the standard HTTP and the HTTP over SSL protocol. HTTPS encrypts and decrypts the page requests and page information between the client browser and the web server of the Power Switch Master using a Secure Socket Layer (SSL). HTTPS by default uses port 443 and HTTP the port 80. A URL beginning with HTTPS indicates that the connection is encrypted using SSL. SSL transactions are negotiated by means of a Key-based encryption algorithm between your browser and the web server of your Power Switch Master. The HTTPS protocol is enabled as default value to achieve the highest security level.

#### HTTP Port

Port used for http connections, default is 80

#### LOGOUT

Click "Logout" at the bottom of the page to exit the session without saving changes.

#### DISCARD CHANGES

Click "Discard Changes" at the bottom of the page to discard all the changes you have made on this page.

#### APPLY CHANGES

Click "Apply Changes" at the bottom of the page to save changes.

### 5.3.2 GENERAL / SYSTEM TIME PAGE

The system time of the Power Switch Master is used to synchronize scheduling actions and to timestamp e-mails and system logging activities. The system time can be set manually (with the browser time of the connected computer) or automatically (with a NTP timeserver).

**BLACK BOX NETWORK SERVICES** Secure Power Switch

General Settings Misc Help

IP Configuration **System Time** SMTP SNMP Tools

**System Time**

Current System Time: Tue 17 Oct 2006 10:00:00

Use Browser Time: ☐ Set System Time

Use NTP Server: ☒ Refresh Time: 12 hours

Primary: time.nist.gov

Secondary: time.windows.com

Time Zone: ☒ (GMT+01:00) Brussels, Copenhagen, Madrid, Paris, Vilnius

Daylight Saving Time: ☒

Start: Month: Mar Week: Last Day: Sun Hour: 02 Minute: 00

End: Month: Oct Week: Last Day: Sun Hour: 03 Minute: 00

LOGOUT DISCARD CHANGES APPLY CHANGES

#### Current System Time

This field shows the current system time of the Power Switch Master. As the system time is displayed through the browser, a small difference (1 to 2 sec) can appear as compared to the exact hour. The system time is nevertheless correct.

#### Use Browser Time

If you want to set the system time using the current Browser time of your PC, select this option and click on the button "Set System Time".

#### Use NTP Server

If you want to set the system time using a NTP timeserver, select this option, choose a refresh interval and enter the IP address of the timeserver you wish to use in the "Primary" field. The address of a second timeserver can be specified in the "Secondary" field. The secondary time server is optional and is used only if the primary timeserver is not available. You can enter either the hostname or the IP address of a NTP server. Note that NTP uses port 123/UDP.

Example: time.PowerSwitch.net or 192.168.1.252

#### Time Zone

Set the time zone corresponding to your location. The system clock will subsequently show local time. Without setting this, the system clock will show UTP. Setting a time zone is only relevant if you are synchronizing with an NTP server.

#### Daylight Saving Time

If you want to set Daylight Saving dates, check this box and specify the date you want to use.

#### LOGOUT

Click "Logout" at the bottom of the page to exit the session without saving changes.

#### DISCARD CHANGES

Click "Discard Changes" at the bottom of the page to discard all the changes you have made on this page.

#### APPLY CHANGES

Click "Apply Changes" at the bottom of the page to save changes.

### 5.3.3 GENERAL / SMTP PAGE

The Power Switch Master can be configured to send e-mails to addresses specified in the Settings/Rules Tab. To send e-mails, you will need a SMTP server on the network and you will have to configure the following parameters:

The screenshot shows the 'SMTP Configuration' page of the 'Secure Power Switch' interface. The page has a header with 'BLACK BOX NETWORK SERVICES' and 'Secure Power Switch'. Below the header is a navigation bar with tabs: General, Settings, Misc, Help, IP Configuration, System Time, SMTP (selected), SNMP, and Tools. The main content area is titled 'SMTP Configuration' and contains the following fields:

- SMTP Client enabled: ☒
- SMTP Server Address:
- SMTP Port:
- From (e-mail Address):

At the bottom of the page are three buttons: **LOGOUT**, **DISCARD CHANGES**, and **APPLY CHANGES**.

#### SMTP Client enabled

Check this box if you want the Power Switch Master to be able to send e-mails.

#### SMTP Server Address

In this field, enter the address of the e-mail server you want to use.

You can enter either the hostname or the IP address of a NTP server.

Example: smtp.yahoo.com or 127.0.0.1

#### SMTP Port

In this field, enter the Port Number you want to use, default and usual value is 25.

#### From Address

In this field, enter the E-Mail address that Power Switch Master messages will appear to come from. This should be a valid address (generally servers reject messages that don't have a valid form address).

#### LOGOUT

Click "Logout" at the bottom of the page to exit the session without saving changes.

#### DISCARD CHANGES

Click "Discard Changes" at the bottom of the page to discard all the changes you have made on this page.

#### APPLY CHANGES

Click "Apply Changes" at the bottom of the page to save changes.

### 5.3.4 GENERAL / SNMP PAGE

SNMP protocol enables to remotely read out the status of all power outlets and the values of all sensors (temperature and/or humidity). It also enables to control individually all power outlets and all groups of power outlets.

**BLACK BOX**  
NETWORK SERVICES

Secure Power Switch

General Settings Misc Help

IP Configuration System Time SMTP **SNMP** Tools

**SNMP Configuration**

SNMP enabled ☒

Contact

Name

Location

Read Community

Write Community ☒

Trap Community ☒

Trap Destination 1 ☒

Trap Destination 2 ☐

☒ LOGOUT ☒ DISCARD CHANGES ☒ APPLY CHANGES

#### SNMP enabled

Check this box if you want to enable the SNMP protocol.

#### Contact

In this field, enter the name you want to give to the contact field. The name can be from 1 to 64 characters long, and can contain alphanumeric characters. Default name is "contact".

#### Name

In this field, enter the name you want to give to the Name field. The name can be from 1 to 64 characters long, and can contain alphanumeric characters. Default name is "name".

#### Location

In this field, enter the name you want to give to the Location field. The name can be from 1 to 64 characters long, and can contain alphanumeric characters. Default name is "location".

#### Read Community

In this field, enter the name you want to give to the Read Community field. The name can be from 1 to 64 characters long, and can contain alphanumeric characters. Default name is "public".

#### Write Community

Check this box if you want to be able to control the power outlets through a MIB browser. In the following field, enter the name you want to give to the Write Community. The name can be from 1 to 64 characters long, and can contain alphanumeric characters. Default name is "private".

#### Trap Community

Check this box if you want to configure the Power Switch SNMP agent to send traps to a community. In the following field, enter the name you want to give to the Trap Community. The name can be from 1 to 64 characters long, and can contain alphanumeric characters. Default name is "trap".

#### Trap Destination 1

Check this box and enter the primary SNMP Server address the traps will be sent to.

#### Trap Destination 2

Check this box and enter the secondary SNMP Server address the traps will be sent to.

#### LOGOUT

Click "Logout" at the bottom of the page to exit the session without saving changes.

#### DISCARD CHANGES


Click "Discard Changes" at the bottom of the page to discard all the changes you have made on this page.

#### APPLY CHANGES

Click "Apply Changes" at the bottom of the page to save changes.

### 5.3.5 GENERAL / TOOLS PAGE

This page enables you to save and download the current system settings. It also enables you to restore the factory settings.



#### Save

Click this button to save the current system settings onto the local hard drive.

#### Load

Click this button and select a setting file you want to download to the Power Switch.

#### Restore

Click this button if you want to restore the factory default settings.

#### Save MIB

Click this button if you want to download the Power Switch Master MIB file onto your local hard drive.

#### LOGOUT

Click "Logout" at the bottom of the page to exit the session without saving changes.

### 5.3.6 SETTINGS / ACCOUNTS PAGE

This page is used to create, activate, deactivate, modify and delete accounts.

- To create an account, click on "Add a New Account" on the right side of the page.

The screenshot shows the 'Accounts' tab in the 'Secure Power Switch' interface. At the top, there's a navigation bar with 'General', 'Settings', 'Misc', and 'Help'. Below it, a sub-navigation bar includes 'Accounts', 'Groups', 'Power Outlets', 'Sensors', 'I/O', and 'Rules'. The main content area is titled 'Accounts' and features a button 'Add a New Account'. A table lists the accounts:

Activated	User Name	Access	Edit	Delete
<input checked="" type="checkbox"/>	admin	Administrator	<input checked="" type="checkbox"/>	<input type="checkbox"/>

At the bottom, there are three buttons: 'LOGOUT', 'DISCARD CHANGES', and 'APPLY CHANGES'.

A new page appears, allowing you to set all parameters of the account.

- To activate or deactivate an account, check or uncheck the corresponding checkbox.
- To modify an account, click on "Edit" of the corresponding account.
- To delete an existing account, click on "Delete" of the corresponding account.

The screenshot shows the 'Add a New Account' form. It includes the following fields:

- User Name:** A text input field.
- Password:** A text input field.
- Confirm Password:** A text input field.
- Groups:** A list of groups with checkboxes: G1: All 8 Outlets of Master, G2: All 8 Outlets of Satellite #1, G3: All 8 Outlets of Master & Sat.
- Device:** A dropdown menu with 'M0: Master Name' selected.
- Power Outlets:** A list of power outlets with checkboxes: M01: Power Outlet 0-1 Name, M02: Power Outlet 0-2 Name, M03: Power Outlet 0-3 Name, M04: Power Outlet 0-4 Name, M05: Power Outlet 0-5 Name, M06: Power Outlet 0-6 Name, M07: Power Outlet 0-7 Name, M08: Power Outlet 0-8 Name.
- Sensor:** A dropdown menu with 'T1: Temperature Rack in Office' selected.
- Sensor Type:** A dropdown menu with 'T11: Temperature' selected.
- Inputs:** A list of inputs with checkboxes: I00: I/O Extension Module Name, I01: Input 1 Name, I02: Input 2 Name, I03: Input 3 Name.
- Outputs:** A list of outputs with checkboxes: O01: Output 1 Name, O02: Output 2 Name, O03: Output 3 Name, O04: Output 4 Name.

At the bottom, there are three buttons: 'LOGOUT', 'DISCARD CHANGES', and 'APPLY CHANGES'.

#### User Name

In this field, enter the name you want to give to the user. The name can be from 1 to 32 characters long, and can contain alphanumeric characters.

#### Password

In this field, enter the password you want to give to the user. The password can be from 4 to 32 characters long, and can contain alphanumeric characters.

#### Confirm Password

In this field, enter again the password.

#### Groups

In this field, you will find all the created groups. If no group has been created, this field is empty.

To add a group or groups of power outlets to the account you are creating, press the Ctrl key and click on the group(s) you want to add. The selected groups are marked dark blue and their names are listed at the right of the field "Groups".

#### Device

In this drop-down list, choose a device from which you want to add power outlets to the current account.



**Power Outlets**

This field is used to add and remove power outlets to/from the current account.

- To add power outlets to the current account, press the Ctrl key and click on the power outlets of the device selected in the field above. The selected power outlets are marked dark blue and their names are listed at the right of the field "Power Outlets".

**Sensor**

In this drop-down list, choose the sensor box you want to add to the current account.

The Power Switch Master supports up to 4 sensor boxes (currently for temperature or temperature and humidity) identified by ID Codes T1 to T16. A character between brackets can follow this ID Code:

- The "X" character means that the corresponding sensor is physically not connected.
- The "!" character means that the corresponding sensor is physically connected but not activated. If you want to activate it, go to the "Settings/Sensors" tab.
- The " " character (blank) means that the corresponding sensor is physically connected and activated.>

**Sensor Type**

This field is used to add and remove sensor types to/from the current account.

- To add sensor types (temperature or humidity) to the current account, press the Ctrl key and click on the sensor types device selected in the field above. The selected sensors are marked dark blue and their names are listed at the right of the field "Sensor types".
- To remove a sensor type, press the Ctrl key and click on the sensor type you wish to remove.

**Inputs**

This field is used to add and remove Inputs to/from the current account.

- To add the I/O extension module or an digital Input to the current account, press the Ctrl key and click on the digital Input selected in the field above. The selected digital inputs are marked dark blue and their names are listed at the right of the field "Inputs".
- To remove a digital Input, press the Ctrl key and click on the digital Input you wish to remove.

**Outputs**

This field is used to add and remove digital Outputs to/from the current account.

- To add a digital Output to the current account, press the Ctrl key and click on the digital Output selected in the field above. The selected digital Outputs are marked dark blue and their names are listed at the right of the field "Outputs".
- To remove a digital Output, press the Ctrl key and click on the digital Output you wish to remove.

**LOGOUT**

Click "Logout" at the bottom of the page to exit the session without saving changes.

**DISCARD CHANGES**

Click "Discard Changes" at the bottom of the page to discard all the changes you have made on this page.


**APPLY CHANGES**

Click "Apply Changes" at the bottom of the page to save changes.

### 5.3.7 SETTINGS / GROUPS PAGE


This page is used to manage groups of power outlets. This functionality is particularly useful if you have to control the power supply of devices using redundant power supplies.

You can create groups including several power outlets distributed on a Power Switch Master and several Power Switch Satellite.



This page is used to create, modify and delete groups.

- To add a new group click on "Add a New Group" on the right side of the page. A new page appears allowing you to set all parameters of the group.
- To delete an existing group, click on "Delete" of the corresponding device.
- To add/remove power outlets to/from an existing group, click on "Edit" of the corresponding device.



#### Group Id

The Power Switch Master automatically creates an ID Code to clearly identify each group of Power Outlets. All the ID Codes used to identify groups start with the character "G".

#### Group Name

In this field, enter the name you want to give to the group. The name can be from 1 to 32 characters long, and can contain alphanumeric characters.

#### Device

In this drop-down list choose a Power Switch from which you want to add power outlets to the group.

#### Power Outlets

This field is used to add/remove power outlets to/from the group.

- To add power outlets to the group, press the Ctrl key and click on the power outlets of the Power Switch device selected in the field above. The selected power outlets are marked dark blue and their names are listed at the right of the field "Power Outlets".
- To remove a power outlet from the group, press the Ctrl key and click on the power outlet you wish to remove.

#### LOGOUT

Click "Logout" at the bottom of the page to exit the session without saving changes.

#### DISCARD CHANGES

Click "Discard Changes" at the bottom of the page to discard all the changes you have made on this page.

#### APPLY CHANGES

Click "Apply Changes" at the bottom of the page to save changes.

### 5.3.8 SETTINGS / POWER OUTLETS PAGE

This page is used to configure all the power outlets of the Power Switch Master and all Power Switch Satellite.

**BLACK BOX NETWORK SERVICES** Secure Power Switch

General Settings Misc Help

Accounts Groups **Power Outlets** Sensors I/O Rules

**Power Outlets**

Activated	ID	Device Name	Detected	Edit
<input checked="" type="checkbox"/>	M0	Master Name	Yes	
<input type="checkbox"/>	S1	Satellite 1 Name	Yes	
<input type="checkbox"/>	S2	Satellite 2 Name	No	
<input type="checkbox"/>	S3	Satellite 3 Name	No	
<input type="checkbox"/>	S4	Satellite 4 Name	No	
<input type="checkbox"/>	S5	Satellite 5 Name	No	
<input type="checkbox"/>	S6	Satellite 6 Name	No	
<input type="checkbox"/>	S7	Satellite 7 Name	No	
<input type="checkbox"/>	S8	Satellite 8 Name	No	
<input type="checkbox"/>	S9	Satellite 9 Name	No	
<input type="checkbox"/>	S10	Satellite 10 Name	No	
<input type="checkbox"/>	S11	Satellite 11 Name	No	
<input type="checkbox"/>	S12	Satellite 12 Name	No	
<input type="checkbox"/>	S13	Satellite 13 Name	No	
<input type="checkbox"/>	S14	Satellite 14 Name	No	
<input type="checkbox"/>	S15	Satellite 15 Name	No	
<input type="checkbox"/>	S16	Satellite 16 Name	No	

LOGOUT DISCARD CHANGES APPLY CHANGES

The main page is also very useful to give an overview of all the Power Switch Satellite that are activated and detected by the Power Switch Master.

- The Power Switch Master can not be deactivated.
- To activate an Power Switch Satellite check the box "Activated" of the corresponding Power Switch Satellite.
- To deactivate an Power Switch Satellite uncheck the box "Activated" of the corresponding Power Switch Satellite. Even if the device remains physically connected to the Master, its power outlets will no longer be accessible by its authorized users.
- To configure or modify the settings of an Power Switch device, click on "Edit" of the corresponding device. A new page appears allowing you to set all parameters of the power outlets.

ID	Designation	Name	Default Power-Up	Power Up Delay (sec)	Delay before Restart (sec)
Master Name					
M01	Power Outlet 1	Power Outlet 0-1 Name	Last St.	0	10
M02	Power Outlet 2	Power Outlet 0-2 Name	Last St.	0	10
M03	Power Outlet 3	Power Outlet 0-3 Name	Last St.	0	10
M04	Power Outlet 4	Power Outlet 0-4 Name	Last St.	0	10
M05	Power Outlet 5	Power Outlet 0-5 Name	Last St.	0	10
M06	Power Outlet 6	Power Outlet 0-6 Name	Last St.	0	10
M07	Power Outlet 7	Power Outlet 0-7 Name	Last St.	0	10
M08	Power Outlet 8	Power Outlet 0-8 Name	Last St.	0	10

[LOGOUT](#)
[DISCARD CHANGES](#)
[APPLY CHANGES](#)

## ID

The Power Switch Master automatically creates an ID Code to clearly identify each Power Outlet.

- All the ID Codes used to identify the power outlets of an Power Switch Master start with the character "M" followed by a number identifying each power outlet.
- All the ID Codes used to identify the power outlets of an Power Switch Satellite start with the character "S" followed by a number identifying each power outlet.

## Name

In this field, enter the name you want to give to the selected device and to each of its power outlets. The name can be from 1 to 32 characters long, and can contain alphanumeric characters.

## Default Power-Up Delay

In the drop-down list choose for each power outlet the default status to apply after power-up.

You can choose between:

- **On** if you want the corresponding power outlet to be always switched to On after power-up.
- **Off** if you want the corresponding power outlet to be always switched to Off after power-up.
- **Last Status** if you want that the corresponding power outlet takes again the state it was in the before power failure.

## Delay before Restart

In this field, enter the Restart Delay you want to define for each power outlet. Restart delay means how long the plug will remain Off before to be switched On again.

The delay can be set between 0 and 65535 seconds.

## LOGOUT

Click "Logout" at the bottom of the page to exit the session without saving changes.

## DISCARD CHANGES

Click "Discard Changes" at the bottom of the page to discard all the changes you have made on this page.

## APPLY CHANGES

Click "Apply Changes" at the bottom of the page to save changes.

### 5.3.9 SETTINGS / SENSORS PAGE

This page is used to configure the temperature and humidity sensors.

Activated	ID	Sensor Name	Detected	Edit
<input checked="" type="checkbox"/>	T1	Sensor 1 Name	Yes	
<input type="checkbox"/>	T2	Sensor 2 Name	Yes	
<input type="checkbox"/>	T3	Sensor 3 Name	No	
<input type="checkbox"/>	T4	Sensor 4 Name	No	
<input type="checkbox"/>	T5	Sensor 5 Name	No	
<input type="checkbox"/>	T6	Sensor 6 Name	No	
<input type="checkbox"/>	T7	Sensor 7 Name	No	
<input type="checkbox"/>	T8	Sensor 8 Name	No	
<input type="checkbox"/>	T9	Sensor 9 Name	No	
<input type="checkbox"/>	T10	Sensor 10 Name	No	
<input type="checkbox"/>	T11	Sensor 11 Name	No	
<input type="checkbox"/>	T12	Sensor 12 Name	No	
<input type="checkbox"/>	T13	Sensor 13 Name	No	
<input type="checkbox"/>	T14	Sensor 14 Name	No	
<input type="checkbox"/>	T15	Sensor 15 Name	No	
<input type="checkbox"/>	T16	Sensor 16 Name	No	

LOGOUT
 DISCARD CHANGES
 APPLY CHANGES

- To activate a Sensor check the box "Activated" of the corresponding device.
- To deactivate a Sensor uncheck the box "Activated" of the corresponding device. Even if the device remains physically connected, it will no longer be accessible by its authorized users.
- To configure or modify the settings of a sensor device, click on "Edit" of the corresponding device. A new page appears allowing you to set all parameters of the sensor device.

Sensor ID:   
 Sensor Name:   
 Sensor Type:

LOGOUT
 DISCARD CHANGES
 APPLY CHANGES

#### Sensor Id

The Power Switch Master automatically creates an ID Code to clearly identify each Sensor. All the ID Codes used to identify Sensors start with the character "T" followed by a number identifying each Sensor.

#### Sensor Name

In this field, enter the name you want to give to the selected sensor. The name can be from 1 to 32 characters long, and can contain alphanumeric characters.

#### Sensor Type

In this drop-down list, choose the sensor type you want to use.

#### LOGOUT

Click "Logout" at the bottom of the page to exit the session without saving changes.

#### DISCARD CHANGES

Click "Discard Changes" at the bottom of the page to discard all changes you have made on this page.

#### APPLY CHANGES

Click "Apply Changes" at the bottom of the page to save changes.

### 5.3.10 SETTINGS / I/O

This page is used to configure the digital Inputs and Outputs of the Secure Power Switch.

All the name can be from 1 to 32 characters long and can contain alphanumeric characters. The pulse delay can be set between 1 and 65535 seconds.

The Secure Power Switch (Master) uses ID Codes to identify the digital inputs and outputs. You will have to know this code if you want to create rules.

"IO0" is used to identify the I/O Extension Module

"IO1" to "IO8" are used to identify the 8 dry contact inputs

"O01" to "O04" are used to identify the 4 dry contact outputs

**Inputs**

ID	Designation	Name
IO0	I/O Extension Module	I/O Extension Module Name
IO1	Input 1	Input 1 Name
IO2	Input 2	Input 2 Name
IO3	Input 3	Input 3 Name
IO4	Input 4	Input 4 Name
IO5	Input 5	Input 5 Name
IO6	Input 6	Input 6 Name
IO7	Input 7	Input 7 Name
IO8	Input 8	Input 8 Name

**Outputs**

ID	Designation	Name	Pulse Delay (sec)
O01	Output 1	Output 1 Name	10
O02	Output 2	Output 2 Name	10
O03	Output 3	Output 3 Name	10
O04	Output 4	Output 4 Name	10

[LOGOUT](#)
[DISCARD CHANGES](#)
[APPLY CHANGES](#)


### 5.3.11 SETTINGS / RULES PAGE

Rules are used to control actions according to a specific event. For example, you can define a rule to switch a power outlet OFF and send an e-mail to a specific user when a predefined temperature is reached or a contact is open.

This page is used to create, modify and delete rules.

- To add a new rule, click on "Add a New Rule" on the right side of the page.  
A new page appears, allowing you to set all the parameters of the rule.
- To remove an existing rule, click on "Delete" of the corresponding rule.
- To modify a rule, click on "Edit" of the corresponding rule.

A total of 255 rules can be created and there are 6 different types of rules.



#### Ping Monitoring Rule

This rule is used to control actions according to the response to a Ping command.

#### Scan Monitoring Rule

This rule is used to control actions according to the response to a Scan command.

#### Dry Contact Monitoring Rule

This rule is used to control actions according to the state of a dry contacts (for example, the dry contact could be connected to a door contact or a fog sensor).

#### Power Supply Monitoring Rule

This rule is used to control actions according to the state of the power supplies of any Master or Satellite Unit.

#### Schedule Rule

This rule is used to control actions according to the scheduler of the Master Unit.

#### Environment Rule

This rule is used to control actions according to environment values (temperature and/or humidity).

### 5.3.12 PING MONITORING RULE

This rule can be used to check if a computer or any IP device is connected to the network. It sends ping packets and listens for replies from the specific host (for more details, see Annexes "Ping and Scan method").

**BLACK BOX NETWORK SERVICES** Secure Power Switch

General Settings Misc Help

Accounts Groups Power Outlets Sensors I/O Rules

**Add a New Monitoring Rule**

Rule ID: R1

Rule Name:

Rule Type: Ping Monitoring Rule

IP Device to monitor: 0.0.0.0

Wait Time for Answer: 0 sec

Interval between Requests: 0 sec

Number of unsuccessful Requests before Action: 0

Delay before First Request after Power Up: 0 sec

Type of Action:

- ☐ Set Power Outlet: 000 - Power Outlet 000 to 000
- ☐ Set Group: 01 - All 0 Outlets of Master to 000
- ☐ Set Dry Contact: 00 - Output 1 Name to 000
- ☐ Send Syslog Message: 00000000 to 00000000
- ☐ Send Trap Message: 00000000 to 0
- ☐ Mail to: 00000000
- ☐ Mail to Syslog / Trap / Mail Message (max 255 characters): 00000000

LOGOUT DISCARD CHANGES APPLY CHANGES

#### Rule ID

The Power Switch Master automatically creates an ID code to clearly identify each rule. All the ID codes used to identify rules start with the character "R" followed by a number.

#### Rule Name

In this field, enter the name you want to give to the rule. The name can be from 1 to 32 characters long, and can contain alphanumeric characters.

#### Rule Type

In this field is displayed the type of the rule you are configuring (Ping Monitoring Rule in that case).

Rules are used to control actions according to specific events. After choosing the type of the rule in the drop-down list, you will have first to configure the event and then to configure the actions to perform.

#### IP device to monitor

In this field, enter the IP address of the IP device that you want to monitor using the Ping command.

#### Wait Time for Answer

In this field, define the delay in seconds for the answer timeout. The delay can be set between 1 and 10 seconds.

#### Interval between Requests

In this field, define the delay in seconds between ping commands sent to the IP device to monitor. The delay can be set between 30 and 65535 seconds.

#### Number of unsuccessful Requests before Action

In this field, define the number of Ping commands to send to the IP device before executing the actions. The number can be set between 1 and 65535 seconds.

#### Delay before first Request after Power Up

In this field, define the time in seconds before restarting the monitoring after the reboot action. The delay can be set between 30 and 65535 seconds.



**Type of action**

For the Ping Monitoring Rule defined above, you can choose and configure the following actions:

**Set Power Outlet**

Check this box and in the corresponding drop-down list, choose the power outlet the rule will apply to. In the next corresponding drop-down list, select the action to execute. Each power outlet can be switched On/Off and restarted. If you choose "restart" you will also be able to define a restart delay between 0 and 65535 seconds.

**Set Group**

!!! This type of action appears and can be configured only if you already have created at least one group (Settings/Groups Tab).

Check this box and in the corresponding drop-down list, choose the power outlet group the rule will apply to. In the next corresponding drop-down list, select the action to execute.

Each power outlet group can be switched On/Off and restarted. If you choose "restart" you will also be able to define a restart delay between 0 and 65535 seconds.

- If you choose 0 second for the delay, the delay will be the delay defined in the "Power Outlets Page".

- If you choose a delay different from 0, the delay will replace the delay set in the "Power Outlets Page".

**Set Dry Contact**

Check this box and in the corresponding drop-down list, choose the dry contact the rule will apply to. In the next corresponding drop-down list, select the action to execute.

Each power dry contact can be Open, Closed or Pulsed (open or close) for a specified delay. The delay can be define between 0 and 65535 seconds.

**Send Syslog Messages**

!!! This type of action appears and can be configured only if you already have configured at least one destination SysLog Server (Misc/Log Settings Page).

Check this box if you want to send a message to a Syslog server. In the following drop-down list choose the facility and the severity of the message to send. The address of the Syslog server has to be defined in the "Log Settings Page".

**Send Trap Message**

!!! This type of action appears and can be configured only if you already have enabled the SNMP protocol and configured the Power Switch Master SNMP agent to send traps to a community (General/SNMP).

**Mail to**

!!! This type of action appears and can be configured only if you already have configured a destination SMTP Server (General/SMTP Page).

Check this/these box(es) and specify one or two e-mails address(es) in the corresponding fields if you want to send an e-mail to one or two specific users. To send e-mails, you will need a SMTP server on the network and you will have to configure the SMTP parameters of the Power Switch on the "General/SMTP Page".

**Syslog / Trap / Mail Message**

!!! This field appears only if you already have configured at least one destination SysLog Server (Misc/Log Settings Page) or a destination SMTP Server (General/SMTP Page).

Up to 255 characters may be entered in this free text field. The text will appear in the Syslog, the Trap and the e-mails.

**LOGOUT**

Click "Logout" at the bottom of the page to exit the session without saving changes.

**DISCARD CHANGES**

Click "Discard Changes" at the bottom of the page to discard all the changes you have made on this page.

**APPLY CHANGES**

Click "Apply Changes" at the bottom of the page to save changes.

### 5.3.13 SCAN MONITORING RULE

This rule can be used to check if a specific protocol is available on a server (for example HTTP, FTP, Telnet, SMTP, POP...). If the connection is possible, Power Switch Master knows that a server program is running there. If the connection is not possible, Power Switch Master can automatically switch the powered device off and after a specified delay switch it again on.

#### Rule ID

The Power Switch Master automatically creates an ID Code to clearly identify each rule. All the ID Codes used to identify rules start with the letter "R" followed by a number.

#### Rule Name

In this field, enter the name you want to give to the rule. The name can be from 1 to 32 characters long, and can contain alphanumeric characters.

#### Rule Type

This field displays the type of the rule you are configuring (Scan Monitoring Rule in that case).

Rules are used to control actions according to specific events. After choosing the type of the rule in the drop-down list, you will have first to configure the event and then to configure the actions to execute.

#### IP device to monitor

In this field enter the IP address of the IP device that you want to monitor using the Scan command. In the "Port to scan" field, enter the port you want to check.

#### Wait Time for Answer

In this field, define the delay in seconds for the answer timeout. The delay can be set between 1 and 10 seconds.

#### Interval between Requests

In this field, define the delay in seconds between scan commands sent to the IP device to monitor. The delay can be set between 30 and 65535 seconds.

#### Number of unsuccessful Requests before Action

In this field, define the number of port scanning commands to send to the IP device before executing the actions. The number can be set between 1 and 65535 seconds.

#### Delay before first Request after Power Up

In this field, define the time in seconds before restarting the monitoring after the reboot action. The delay can be set between 30 and 65535 seconds.

**Type of action**

For the Event defined above, you can choose and configure the following actions:

**Set Power Outlet**

Check this box and in the corresponding drop-down list, choose the power outlet the rule will apply to. In the next corresponding drop-down list, choose the action to perform. Each power outlet can be switched On/Off and restarted. If you choose "restart" you will also be able to define a restart delay between 0 and 65535 seconds.

**Set Group**

!!! This type of action appears and can be configured only if you already have created at least one group (Settings/Groups Tab).

Check this box and in the corresponding drop-down list, choose the power outlet group the rule will apply to. In the next corresponding drop-down list, choose the action to perform.

Each power outlet group can be switched On/Off or restarted. If you choose "restart" you will also be able to define a restart delay between 0 and 65535 seconds.

- If you choose 0 second for the delay, the delay will be the delay defined in the "Power Outlets Page".

- If you choose a delay different from 0, the delay will replace the delay defined in the "Power Outlets Page".

**Set Dry Contact**

Check this box and in the corresponding drop-down list, choose the dry contact the rule will apply to. In the next corresponding drop-down list, choose the action to perform.

Each power dry contact can be Open, Closed or Pulsed (open or close) for a specified delay. The delay can be define between 0 and 65535 seconds.

**Send Syslog Messages**

!!! This type of action appears and can be configured only if you already have configured at least one destination SysLog Server (Misc/Log Settings Page).

Check this box if you want to send a message to a Syslog server. In the following drop-down list, choose the facility and the severity of the message to send. The address of the Syslog server has to be defined in the "Log Settings Page".

**Send Trap Message**

!!! This type of action appears and can be configured only if you already have enabled the SNMP protocol and configured the Power Switch Master SNMP agent to send traps to a community (General/SNMP).

**Mail to**

!!! This type of action appears and can be configured only if you already have configured a destination SMTP Server (General/SMTP Page).

Check this/these box(es) and specify one or two e-mails address(es) in the corresponding fields if you want to send an e-mail to one or two specific users. To send e-mails, you will need a SMTP server on the network and you will have to configure the SMTP parameters of the Power Switch on the "General/SMTP Page".

**Syslog / Trap / Mail Message**

!!! This field appears only if you already have configured at least one destination SysLog Server (Misc/Log Settings Page) or a destination SMTP Server (General/SMTP Page).

Up to 255 characters may be entered in this free text field. The text will appear in the Syslog, the Trap and the e-mails.

**LOGOUT**

Click "Logout" at the bottom of the page to exit the session without saving changes.

**DISCARD CHANGES**

Click "Discard Changes" at the bottom of the page to discard all the changes you have made on this page.

**APPLY CHANGES**

Click "Apply Changes" at the bottom of the page to save changes.

### 5.3.14 DRY CONTACT MONITORING RULE

This rule is used to control actions according to the state of any dry contacts (for example, the dry contact could be connected to a door contact or a fog sensor).

#### Rule ID

The Power Switch Master automatically creates an ID code to clearly identify each rule. All the ID codes used to identify rules start with the letter "R" followed by a number.

#### Rule Name

In this field, enter the name you want to give to the rule. The name can be from 1 to 32 characters long, and can contain alphanumeric characters.

#### Rule Type

This field displays the type of the rule you are configuring (Dry Contact Monitoring Rule in this case).

Rules are used to control actions according to specific events. After choosing the type of the rule in the drop-down list, you will have first to configure the event and then to configure the actions to perform.

#### Dry contact to monitor

In this Drop-Down list, choose the I/O Module or Dry Contact Input you want to monitor. The Power Switch Master uses ID codes to clearly identify each Input.

- The ID code used to identify the I/O module is IO0,
- The ID codes used to identify Dry Contact Inputs start with the letter "I" followed by a number, 01 for dry contact 1, 02 for dry contact 2...

#### Action if I/O Module has been ... (if Dry contact to monitor = I/O Module IO0)

In this Drop-Down list, choose if the action has to be executed if the I/O Module has been connected or disconnected.

#### Action if Dry Contact has been ...

In this Drop-Down list, choose if the action has to be executed if the contact has been open or closed.

#### Type of action

For the Dry Contact Monitoring Rule defined above, you can choose and configure the following actions:

#### Set Power Outlet

Check this box and in the corresponding drop-down list, choose the power outlet the rule will apply to. In the next corresponding drop-down list, select the action to execute. Each power outlet can be switched On/Off and restarted. If you choose "restart" you will also be able to define a restart delay between 0 and 65535 seconds.

**Set Group**

!!! This type of action appears and can be configured only if you already have created at least one group (Settings/Groups Tab). Check this box and in the corresponding drop-down list, choose the power outlet group the rule will apply to. In the next corresponding drop-down list, choose the action to perform. Each power outlet group can be switched On/Off and restarted. If you choose "restart" you will also be able to define a restart delay between 0 and 65535 seconds.

- If you choose 0 second for the delay, the delay will be the delay defined in the "Power Outlets Page".
- If you choose a delay different from 0, the delay will replace the delay defined in the "Power Outlets Page".

**Set Dry Contact**

Check this box and in the corresponding drop-down list, choose the dry contact the rule will apply to. In the next corresponding drop-down list, choose the action to perform.

Each power dry contact can be Open, Closed or Pulsed (open or close) for a specified delay. The delay can be define between 0 and 65535 seconds.

**Send Syslog Messages**

!!! This type of action appears and can be configured only if you already have configured at least one destination SysLog Server (Misc/Log Settings Page). Check this box if you want to send a message to a Syslog server. In the following drop-down list, choose the facility and the severity of the message to send. The address of the Syslog server has to be defined in the "Log Settings Page".

**Send Trap Message**

!!! This type of action appears and can be configured only if you already have enabled the SNMP protocol and configured the Power Switch SNMP agent to send traps to a community (General/SNMP).

**Mail to**

!!! This type of action appears and can be configured only if you already have configured a destination SMTP Server (General/SMTP Page). Check this/these box(es) and specify one or two e-mails address(es) in the corresponding fields if you want to send an e-mail to one or two specific users. To send e-mails, you will need a SMTP server on the network and you will have to configure the SMTP parameters of the Power Switch on the "General/SMTP Page".

**Syslog / Trap / Mail Message**

!!! This field appears only if you already have configured at least one destination SysLog Server (Misc/Log Settings Page) or a destination SMTP Server (General/SMTP Page). Up to 255 characters may be entered in this free text field. The text will appear in the Syslog, the Trap and the e-mails.

**LOGOUT**

Click "Logout" at the bottom of the page to exit the session without saving changes.

**DISCARD CHANGES**

Click "Discard Changes" at the bottom of the page to discard all the changes you have made on this page.

**APPLY CHANGES**

Click "Apply Changes" at the bottom of the page to save changes.

**Example**

You want to monitor the entrance door of your data centre and in case of intrusion you want to send a message to a Syslog server and receive an e-mail.

**You need:**

- the Power Switch I/O extension board
- a door contact switch with an external magnetic contact
- 2 wire cables

**Installation:**

- Connect the Power Switch I/O extension board to the SUB-D 25 connector of the Power Switch Master using the cable supplied with the I/O extension board
- Connect the 2 wires of the door contact to the Dry Contact Input 1 (DC1). The door contact can be located up to 10 meters from the I/O extension board.

**Event configuration:**

- Click on the Settings Tab, then on the Rules Tab
- Click on Add a New Rule
- In "Type of the Rule", choose "Dry Contact Monitoring Rule"
- In "Dry Contact to monitor", choose "I01" (if you connected the door contact on Input 1)
- In "Action", choose "open" (normally the door contact switch opens when the door is open).

**Action configuration:**

- Check the box "Send Syslog Message" and choose the Facility and the Severity you want to give to the Syslog message.
- Check the box "Mail to" and specify the e-mail address the e-mail has to be sent to.

### 5.3.15 POWER SUPPLY MONITORING RULE

This rule can be used to monitor the status of the power supplies of each Power Switch Master and Power Switch Satellite.

**BLACK BOX NETWORK SERVICES** Secure Power Switch

General Settings Misc Help

Accounts Groups Power Outlets Sensors I/O Rules

**Add a New Monitoring Rule**

Rule ID: R1

Rule Name:

Rule Type: Power Supply Monitoring Rule

Device to monitor: M0: Master Name

Power supply to monitor: Power Supply A

Action if Power Supply...: Restored

Type of Action:

- ☐ Set Power Outlet: Set Power Outlet 0-1 Name to
- ☐ Set Group: Set Group 0-1 Name to
- ☐ Set Dry Contact: Set Dry Contact 0-1 Name to
- ☐ Send Syslog Message: Send Syslog Message to
- ☐ Send Trap Message: Send Trap Message to
- ☐ Mail to: Mail to
- ☐ Mail to: Mail to
- ☐ Syslog / Trap / Mail Message (max 255 characters):

LOGOUT DISCARD CHANGES APPLY CHANGES

#### Rule ID

The Power Switch Master automatically creates an ID Code to clearly identify each rule. All the ID Codes used to identify rules start with the character "R" followed by a number.

#### Rule Name

In this field, enter the name you want to give to the rule. The name can be from 1 to 32 characters long, and can contain alphanumeric characters.

#### Rule Type

In this Drop-Down list, choose Power Supply Monitoring Rule.

Rules are used to control actions according to specific events. First you will have to configure the chosen event as follows, then you will choose the actions to execute.

#### Device to monitor

In this Drop-Down list, choose the device for which you want to monitor the power supply.

Each device name is preceded by the ID Code of the device (M0 for the Master, S1 for the Satellite 1, S2 for the Satellite 2...).

A character between brackets can follow this ID Code:

- The "X" character means that the corresponding Satellite is physically not connected.
- The "!" character means that the corresponding Satellite is physically connected but not activated. If you want to activate it, go to the "Settings/Power Outlets" tab.
- The " " character (blank) means that the corresponding Satellite is physically connected and activated.>

**Power Supply to monitor**

In this Drop-Down list, choose the power supply you wish to monitor.

- If in the previous drop-down list, you choose Master unit (ID Code M0), you can choose to monitor the power supply input A, the Power supply input B and the auxiliary power supply input located on the front panel of the Master unit.

Power supply A is used for the power outlets 1 to 4 and of course to supply the Webserver.

Power supply B is used for the power outlets 5 to 8 and of course to supply the Webserver.

Auxiliary Power Supply is used only for the Web server.

- If in previous drop-down list, you choose a Satellite unit (ID Code S1 to S16), you can choose to monitor the power supply input A and the Power supply input B.

Power supply A is used for the power outlets 1 to 4 and of course to supply the electronic circuits of the Satellite. Power supply B is used for the power outlets 5 to 8 and of course to supply the electronic circuits of the Satellite.

**Action if Power Supply...**

In this Drop-Down list, choose if the action has to be executed on power failure or power on (or restored).

**Type of action**

For the Power Supply Monitoring Rule defined above, you can choose and configure the following actions:

**Set Power Outlet**

Check this box and in the corresponding drop-down list, choose the power outlet the rule will apply to. In the next corresponding drop-down list, choose the action to execute. Each power outlet can be switched On/Off and restarted. If you choose "restart" you will also be able to define a restart delay between 0 and 65535 seconds.

**Set Group**

!!! This type of action appears and can be configured only if you already have created at least one group (Settings/Groups Tab). Check this box and in the corresponding drop-down list, choose the power outlet group the rule will apply to. In the next corresponding drop-down list, choose the action to execute. Each power outlet group can be switched On/Off and restarted. If you choose "restart" you will also be able to define a restart delay between 0 and 65535 seconds.

- If you choose 0 second for the delay, the delay will be the delay set in the "Power Outlets Page".

- If you choose a delay different from 0, the delay will replace the delay set in the "Power Outlets Page".

**Set Dry Contact**

Check this box and in the corresponding drop-down list, choose the dry contact the rule will apply to. In the next corresponding drop-down list, choose the action to execute.

Each power dry contact can be Open, Closed or Pulsed (open or close) for a specified delay. The delay can be define between 0 and 65535 seconds.

**Send Syslog Messages**

!!! This type of action appears and can be configured only if you already have configured at least one destination SysLog Server (Misc/Log Settings Page). Check this box if you want to send a message to a Syslog server. In the following drop-down lists, choose the facility and the severity of the message to send. The address of the Syslog server has to be defined in the "Log Settings Page".

**Send Trap Message**

!!! This type of action appears and can be configured only if you already have enabled the SNMP protocol and configured the Power Switch SNMP agent to send traps to a community (General/SNMP).

**Mail to**

!!! This type of action appears and can be configured only if you already have configured a destination SMTP Server (General/SMTP Page).

Check this/these box(es) and specify one or two e-mails address(es) in the corresponding fields if you want to send an e-mail to one or two specific users. To send e-mails, you will need a SMTP server on the network and you will have to configure the SMTP parameters of the Power Switch on the "General/SMTP Page".

**Syslog / Trap / Mail Message**

!!! This field appears only if you already have configured at least one destination SysLog Server (Misc/Log Settings Page) or a destination SMTP Server (General/SMTP Page).

Up to 255 characters may be entered in this free text field. The text will appear in the Syslog, the Trap and the e-mails.

**LOGOUT**

Click "Logout" at the bottom of the page to exit the session without saving changes.

**DISCARD CHANGES**

Click "Discard Changes" at the bottom of the page to discard all the changes you have made on this page.

**APPLY CHANGES**

Click "Apply Changes" at the bottom of the page to save changes.

### 5.3.16 SCHEDULE RULE

This rule can be used to execute some actions according to a defined time table.

**BLACK BOX NETWORK SERVICES** Secure Power Switch

General Settings Misc Help

Accounts Groups Power Outlets Sensors I/O Rules

**Add a New Monitoring Rule**

Rule ID: R1

Rule Name:

Rule Type: Schedule Rule

Schedule Action

Start: Hour: 00 Minute: 00

Every ☐ Sun ☐ Mon ☐ Tue ☐ Wed ☐ Thu ☐ Fri ☐ Sat

Type of Action

- ☐ Set Power Outlet: [001 - Power Outlet 0-3 Name] to [On]
- ☐ Set Group: [01 - All 8 Outlets of Master] to [On]
- ☐ Set Dry Contact: [001 - Output 1 Name] to [Open]
- ☐ Send Syslog Message: [Local host] [Emergency]
- ☐ Send Trap Message: [001-Trap] [0]
- ☐ Mail to:
- ☐ Mail to:
- ☐ Syslog / Trap / Mail Message (max 255 characters):

LOGOUT DISCARD CHANGES APPLY CHANGES

#### Rule ID

The Power Switch Master automatically creates an ID code to clearly identify each rule. All the ID codes used to identify rules start with the character "R" followed by a number.

#### Rule Name

In this field, enter the name you want to give to the rule. The name can be from 1 to 32 characters long, and can contain alphanumeric characters.

#### Rule Type

In this Drop-Down list, choose Schedule Rule.

Rules are used to control actions according to a specific event. First you will have to configure the chosen event as follows, then you will choose the actions to perform.

#### Schedule Action

Here you can define the time when the rule has to be executed.

In the Drop-Down lists, choose the time and below, check one or more day boxes.

#### Type of action

For the Schedule Rule defined above, you can choose and configure the following actions:

#### Set Power Outlet

Check this box and in the corresponding drop-down list, choose the power outlet the rule will apply to. In the next corresponding drop-down list, choose the action to perform. Each power outlet can be switched On/Off and restarted. If you choose "restart" you will also be able to define a restart delay between 0 and 65535 seconds.



**Set Group**

!!! This type of action appears and can be configured only if you already have created at least one group (Settings/Groups Tab). Check this box and in the corresponding drop-down list, choose the power outlet group the rule will apply to. In the next corresponding drop-down list, choose the action to perform.

Each power outlet group can be switched On/ Off and restarted. If you choose "restart" you will also be able to define a restart delay between 0 and 65535 seconds.

- If you choose 0 second for the delay, the delay will be the delay set in the "Power Outlets Page".

- If you choose a delay different from 0, the delay will replace the delay set in the "Power Outlets Page".

**Set Dry Contact**

Check this box and in the corresponding drop-down list, choose the dry contact the rule will apply to. In the next corresponding drop-down list, choose the action to perform.

Each power dry contact can be Open, Closed or Pulsed (open or close) for a specified delay. The delay can be define between 0 and to 65535 seconds.

**Send Syslog Messages**

!!! This type of action appears and can be configured only if you already have configured at least one destination SysLog Server (Misc/Log Settings Page). Check this box if you want to send a message to a Syslog server. In the following drop-down lists, choose the facility and the severity of the message to send. The address of the Syslog server has to be defined in the "Log Settings Page".

**Send Trap Message**

!!! This type of action appears and can be configured only if you already have enabled the SNMP protocol and configured the Power Switch SNMP agent to send traps to a community (General/SNMP).

**Mail to**

!!! This type of action appears and can be configured only if you already have configured a destination SMTP Server (General/SMTP Page). Check this/these box(es) and specify one or two e-mails address(es) in the corresponding fields if you want to send an e-mail to one or two specific users. To send e-mails, you will need a SMTP server on the network and you will have to configure the SMTP parameters of the Power Switch on the "General/SMTP Page".

**Syslog / Trap / Mail Message**

!!! This field appears only if you already have configured at least one destination SysLog Server (Misc/Log Settings Page) or a destination SMTP Server (General/SMTP Page).

Up to 255 characters may be entered in this free text field. The text will appear in the Syslog, the Trap and the e-mails.

**LOGOUT**

Click "Logout" at the bottom of the page to exit the session without saving changes.

**DISCARD CHANGES**

Click "Discard Changes" at the bottom of the page to discard all the changes you have made on this page.

**APPLY CHANGES**

Click "Apply Changes" at the bottom of the page to save changes.

### 5.3.17 ENVIRONMENT RULE

This rule can be used to monitor a temperature or a humidity value and perform actions when the predefined value is exceeded.

**BLACK BOX NETWORK SERVICES** Secure Power Switch

General Settings Misc Help

Accounts Groups Power Outlets Sensors I/O Rules

**Add a New Monitoring Rule**

Rule ID: R1

Rule Name:

Rule Type: Environment Rule

Sensor to monitor: T1: Temperature Rack in Office

Sensor Type: Temperature

Action if...:
 

- ☒ Lower than 0 °C
- ☐ Higher than 0 °C

Type of Action:
 

- ☐ Set Power Outlet: [Dropdown] to [Dropdown]
- ☐ Set Group: [Dropdown] to [Dropdown]
- ☐ Set Dry Contact: [Dropdown] to [Dropdown]
- ☐ Send Syslog Message: [Dropdown] [Dropdown]
- ☐ Send Trap Message: [Dropdown] 0
- ☐ Mail to: [Text Box]
- ☐ Mail to: [Text Box]
- ☐ Syslog / Trap / Mail Message (max 255 characters): [Text Area]

LOGOUT DISCARD CHANGES APPLY CHANGES

#### Rule ID

The Power Switch Master automatically creates an ID code to clearly identify each rule. All the ID codes used to identify rules start with the character "R" followed by a number.

#### Rule Name

In this field, enter the name you want to give to the rule. The name can be from 1 to 32 characters long, and can contain alphanumeric characters.

#### Rule Type

In this Drop-Down list, choose Environment Rule.

Rules are used to control actions according to a specific event. First you will have to configure the chosen event as follows, then you will choose the actions to perform.

#### Sensor to monitor

Choose in this Drop-Down list the sensor you want to monitor.

The Power Switch Master supports up to 16 sensors and each sensor name, which can be defined by the administrator (go to Settings/Sensors Tab), is preceded by the ID code of the sensor. All ID codes used to identify temperature and temperature/humidity sensors start with the character "T" followed by a number.

This ID code can be followed by a character between brackets:

- The "X" character means that the corresponding sensor is physically not connected.
- The "!" character means that the corresponding sensor is physically connected but not activated. If you want to activate it, go to the "Settings/Sensors" tab.
- The " " character (blank) means that the corresponding sensor is physically connected and activated.

#### Sensor type to monitor

According to the sensor model you use, choose temperature or humidity in this Drop-Down list. Two sensor models are available (see the label on the back of your sensor box): the first one uses a temperature sensor and the second one a temperature and humidity sensor.

**Action if...**

The options "lower than" and "higher than" enables you to define when the rule has to be executed.

- Choose "lower than" if you want to execute the rule if the environment value is below the value you defined in the field on the right of "lower than".
- Choose "higher than" if you want to execute the rule if the environment value exceeds the value you defined in the field on the right of "higher than".

For temperature, you can define values between 0° and 50 °C

For relative humidity, you can define values between 10 RH and 90 RH

**Type of action**

For the Environment Rule defined above, you can choose and configure the following actions:

**Set Power Outlet**

Check this box and in the corresponding drop-down list, choose the power outlet the rule will apply to. In the next corresponding drop-down list, choose the action to execute. Each power outlet can be switched On/Off and restarted. If you choose "restart" you will also be able to define a restart delay between 0 and 65535 seconds.

**Set Group**

!!! This type of action appears and can be configured only if you already have created at least one group (Settings/Groups Tab). Check this box and in the corresponding drop-down list, choose the power outlet group the rule will apply to. In the next corresponding drop-down list, choose the action to perform. Each power outlet group can be switched On/Off and restarted. If you choose "restart" you will also be able to define a restart delay between 0 and 65535 seconds.

- If you choose 0 second for the delay, the delay will be the delay defined in the "Power Outlets Page".
- If you choose a delay different from 0, the delay will replace the delay defined in the "Power Outlets Page".

**Set Dry Contact**

Check this box and in the corresponding drop-down list, choose the dry contact the rule will apply to. In the next corresponding drop-down list, choose the action to execute. Each power dry contact can be switched Open, Closed or Pulsed (open or close) for a specified delay. The delay can be define between 0 and 65535 seconds.

**Send Syslog Messages**

!!! This type of action appears and can be configured only if you already have configured at least one destination SysLog Server (Misc/Log Settings Page). Check this box if you want to send a message to a Syslog server. In the following drop-down list, choose the facility and the severity of the message to send. The address of the Syslog server has to be defined in the "Log Settings Page".

**Send Trap Message**

!!! This type of action appears and can be configured only if you already have enabled the SNMP protocol and configured the Power Switch Master SNMP agent to send traps to a community (General/SNMP).

**Mail to**

!!! This type of action appears and can be configured only if you already have configured a destination SMTP Server (General/SMTP Page). Check this/these box(es) and specify one or two e-mails address(es) in the corresponding fields if you want to send an e-mail to one or two specific users. To send e-mails, you will need a SMTP server on the network and you will have to configure the SMTP parameters of the Power Switch on the "General/SMTP Page".

**Syslog / Trap / Mail Message**

!!! This field appears only if you already have configured at least one destination SysLog Server (Misc/Log Settings Page) or a destination SMTP Server (General/SMTP Page). Up to 255 characters may be entered in this free text field. The text will appear in the Syslog, the Trap and the e-mails.

**LOGOUT**

Click "Logout" at the bottom of the page to exit the session without saving changes.

**DISCARD CHANGES**

Click "Discard Changes" at the bottom of the page to discard all the changes you have made on this page.

**APPLY CHANGES**

Click "Apply Changes" at the bottom of the page to save changes.

### 5.3.18 MISC / PERIPHERALS PAGE

This page displays the ID, Type and Name of all detected peripherals.

If you want to know the actual firmware version of the connected peripherals, click on the corresponding "Info" button. For the Power Switch Master and Satellite you will also have access to the switching operations counters of each power outlet. This counter can be reset by clicking the "Clear All Counters" button on the bottom of the page.

**BLACK BOX**  
NETWORK SERVICES

Secure Power Switch

General Settings Misc Help

Peripherals I/O Status Log Log Settings

➔ Detected Peripherals ?

ID	Type	Name	Activated	Info
M0	Secure Power Switch PSE518 MA	Master Name	Yes	✓
S1	Secure Power Switch PSE518 SA	Satellite 1 Name	Yes	✓
T1	Secure Power Switch PSE518 T	Temperature Rack in Office	Yes	✓
T2	Secure Power Switch PSE518 TH	Temp. & Humidity Rack right side	Yes	✓

✗ LOGOUT

### 5.3.19 MISC / I/O STATUS

This page displays the status of the 4 dry contact outputs and the 8 dry contact inputs of the Power Switch Master. It also displays if an I/O Extension Module is connected to the I/O connector on the front panel of the Power Switch Master.

The Power Switch Master uses ID codes to identify the inputs and outputs. You will have to know this code if you want to create rules.

"I00" is used to identify the I/O Extension Module

"O01" to "O04" are used to identify the 4 dry contact outputs"

"I01" to "I08" are used to identify the 8 dry contact inputs.

**BLACK BOX**  
NETWORK SERVICES

**Secure Power Switch**

General Settings **Misc** Help

Peripherals **I/O Status** Log Log Settings

**I/O Status**

ID	Name	Status
I00	I/O Extension Module Name	Disconnected


ID	Name	Status
I01	Input 1 Name	Open
I02	Input 2 Name	Open
I03	Input 3 Name	Open
I04	Input 4 Name	Open
I05	Input 5 Name	Open
I06	Input 6 Name	Open
I07	Input 7 Name	Open
I08	Input 8 Name	Open

ID	Name	Status
O01	Output 1 Name	Closed
O02	Output 2 Name	Closed
O03	Output 3 Name	Closed
O04	Output 4 Name	Closed

**LOGOUT**

### 5.3.20 MISC / LOG PAGE

This page allows you to configure the logs. The Log file is used by the system to record actions, warnings, errors and problems. It is often quite useful to discover the causes of tricky problems. The messages recorded in the log file and sent as copy to a Syslog server are classified into 8 severity levels (Emergency, Alert, Critical, Error, Warning, Notice, Informational and Debug).



**BLACK BOX**  
NETWORK SERVICES

Secure Power Switch

General Settings Misc Help

Peripherals I/O Status Log Log Settings

**Log**

Informational	18 May 2005 15:38:28	Administrator Session open by "admin"
Informational	18 May 2005 15:12:54	Date & Time have been synchronized to a Network Time Server
Informational	18 May 2005 15:04:44	Administrator Session closed by "admin"
Informational	18 May 2005 14:55:58	Administrator Session open by "admin"
Informational	18 May 2005 14:54:37	Administrator Session closed by "admin"
Informational	18 May 2005 14:40:55	Administrator Session open by "admin"
Informational	18 May 2005 14:20:16	Administrator Session closed by "admin"
Informational	18 May 2005 14:13:08	Administrator Session open by "admin"
Informational	18 May 2005 14:13:08	User Session closed by "admin"
Informational	18 May 2005 14:12:48	Date & Time have been synchronized to a Network Time Server
Informational	18 May 2005 14:09:25	User Session open by "admin"
Informational	18 May 2005 13:12:50	Date & Time have been synchronized to a Network Time Server
Informational	18 May 2005 12:12:55	Date & Time have been synchronized to a Network Time Server
Informational	18 May 2005 11:12:54	Date & Time have been synchronized to a Network Time Server
Informational	18 May 2005 10:12:50	Date & Time have been synchronized to a Network Time Server
Informational	18 May 2005 09:12:50	Date & Time have been synchronized to a Network Time Server
Informational	18 May 2005 08:12:50	Date & Time have been synchronized to a Network Time Server
Informational	18 May 2005 07:12:51	Date & Time have been synchronized to a Network Time Server
Informational	18 May 2005 06:12:51	Date & Time have been synchronized to a Network Time Server

**LOGOUT** **CLEAR LOG**

### 5.3.21 MISC / LOG SETTINGS PAGE

Power Switch Master can output Syslog messages and/or send selected logs to a specific e-mail address. The logs are often quite useful for discovering the causes of tricky problems. For the logs to be sent to a specific e-mail address, the administrator can choose the severity of the messages to be sent.

#### Primary Syslog Server / Secondary Syslog Server

If you want to enable the Power Switch Master to send messages to one or two Syslog Server(s), check the box "Primary Syslog Server" and where appropriate "Secondary Syslog Server" and enter the address(es) of the Syslog Server(s) you wish to use. You can enter either the hostname or the IP address of a Syslog server. Power Switch Master uses the usual UDP Port 514 to output Syslog messages.

Example: syslog.PowerSwitch.com or 192.168.1.252

#### E-Mail Address

If you want to enable the Power Switch Master to send e-mails, check the box "e-mail address" and specify the destination e-mail address to be used.

The E-Mail address can be from 1 to 64 characters long, and can contain alphanumeric characters.

#### Type of messages to send

Specify in this field the severity of the messages you want to send to the specified e-mail address. The messages are classified in 8 severity Levels (see Syslog Messages: Severity Level Definition).

#### LOGOUT

Click "Logout" at the bottom of the page to exit the session without saving changes.

#### DISCARD CHANGES


Click "Discard Changes" at the bottom of the page to discard all the changes you have made on this page.

#### APPLY CHANGES

Click "Apply Changes" at the bottom of the page to save changes.

## 6. Controlling the Power Outlets of the Master and Satellites

1. Start your Web browser and type the IP address of your Power Switch Master. The browser displays the authentication dialog box.



2. Enter a user name and its corresponding password.
  - ❑ If you log in as system administrator, you will be able to:
    - control individually all the power outlets and all the power outlets groups of the Power Switch Master,
    - control all the power outlets and all the power outlet groups of the connected Power Switch satellites,
    - display the values of all the connected temperature and humidity sensors,
    - display the connection status of the I/O extension module and the status of the eight dry contact inputs.
  - ❑ If you log in as a user (Power Switch 518 MA handles up to 255 accounts), you will be able to:
    - control individually all the power outlets and all the power outlet groups for which you have the rights,
    - display the values of all the connected temperature and humidity sensors for which you have the rights.

The **ON** button allows you to switch to ON the corresponding Power Outlet or group of Power Outlets.  
 The **OFF** button allows you to switch to OFF the corresponding Power Outlet or group of Power Outlets.  
 The **Restart** button allows you to switch OFF the corresponding Power Outlet or group of Power Outlets.  
 The Power Outlet(s) will be then automatically switched ON after the delay defined by the administrator during the configuration (default value is 10 sec).




## 7. Installation the Power Switch Satellite

### Remark:

Make sure that all the Power Switch devices are powered off.

### Connection Instructions

1. Connect the supplied RJ11 link-up cable to one of the xBus connector of the Power Switch Master and to one of the xBus connector of the Power Switch Satellite. To cascade several Satellites, link the second xBus connector of a Satellite with one of the xBus connector of the next Satellite.



2. Allocate an address to each Satellite by positioning the address selection DIP-switches marked "Slct" on the front panel according to the following table.

### Remarks

- Unplug the power cords of the Power Switch Satellite before changing its DIP switches.
- Do NOT use the same address for two different Satellites.

Satellite Address	DIP-Switch 1	DIP-Switch 2	DIP-Switch 3	DIP-Switch 4
1	Off	Off	Off	Off
2	[ON]	Off	Off	Off
3	Off	[ON]	Off	Off
4	[ON]	[ON]	Off	Off
5	Off	Off	[ON]	Off
6	[ON]	Off	[ON]	Off
7	Off	[ON]	[ON]	Off
8	[ON]	[ON]	[ON]	Off
9	Off	Off	Off	[ON]
10	[ON]	Off	Off	[ON]
11	Off	[ON]	Off	[ON]
12	[ON]	[ON]	Off	[ON]
13	Off	Off	[ON]	[ON]
14	[ON]	Off	[ON]	[ON]
15	Off	[ON]	[ON]	[ON]
16	[ON]	[ON]	[ON]	[ON]

Position Off = switch upwards,  
Position On = switch downwards  
  
DIP-Switch 1 is located on the left side

3. Plug the 2 power cables into 2 grounded sockets. The A and B LEDs light on to confirm that power is on.

## 8. Controlling the Power Outlets of the Satellites using a Terminal Connection

The power outlets of the Power Switch Satellites can be individually controlled and the status of each power outlet can be read out using a simple ASCII protocol through a serial connection. The connection can be done either using the RS232 or the RS485 port of the Power Switch PS518 Satellite.

### 8.1 Using the RS232 port

(SubD-9F connector marked RS232 on the front panel)

In this case, use the supplied RS232 serial cable to connect the Power Switch Satellite to an available serial port of your PC.

### 8.2 Using the RS485 port

(RJ11 connector marked xBus on the front panel)

In this case, you have to make a special serial cable (see pinout on the following page).

Run a terminal program such as Windows HyperTerminal or the MicroTerminal program on the CD (folder miscellaneous) and configure the appropriate serial port with the following settings:  
9.600 bauds, 8 bits, no parity, 1 stop bit and no flow control.

#### Note:

If you use the MicroTerminal program on the CD (folder miscellaneous) you only have to choose the used serial port, this program is already configured at 9600,n,8,1.

### 8.3 Commands

Run a terminal program such as Windows HyperTerminal or the MicroTerminal program on the CD (folder miscellaneous) and configure the appropriate serial port with the following settings:  
9.600 bauds, 8 bits, no parity, 1 stop bit and no flow control.

#### Note:

If you use the MicroTerminal program on the CD (folder miscellaneous) you only have to choose the used serial port, this program is already configured at 9600,n,8,1.

#### Summary of the commands:

Controlling of the Power Outlet(s)	⇒ § 8.3.1
Reading out the Status of the Power Outlet(s)	⇒ § 8.3.2
Setting the Power Up Delays	⇒ § 8.3.3
Reading out of the Power Up Delays	⇒ § 8.3.4
Setting the Restart Delays	⇒ § 8.3.5
Reading out the Restart Delays	⇒ § 8.3.6
Setting the Power Up Default Status	⇒ § 8.3.7
Reading out the Power Up Default Status	⇒ § 8.3.8
Reading out the Switching Counters of the Relays	⇒ § 8.3.9
Resetting the Switching Counters of the Relays	⇒ § 8.3.10
Restoring to Factory Settings	⇒ § 8.3.11

### 8.3.1 CONTROLLING OF THE POWER OUTLET(S)

This command enables to control individually each Power Outlet or all Power Outlets of the same Power Switch Satellite in one command.

**Command to be sent to the Power Switch Satellite:**

Pxy=z[CR]

Pxy=z,t<sub>1</sub>[CR]

Pxy=z,t<sub>1</sub>,t<sub>2</sub>[CR]

**Reply from the Power Switch Satellite:**

Pxy=z[CR]

Pxy=z,t<sub>1</sub>[CR]

Pxy=z,t<sub>1</sub>,t<sub>2</sub>[CR]

**Explanations:**

Parameter		Value	Function/Remark
<b>x</b>	address of the Power Switch	1 to 16	specifies the address of the Power Switch Satellite
<b>y</b>	number of the Power Outlet	0 1 to 8	means all the Power Outlets specify the number of the Power Outlet
<b>z</b>	command	0	set Power Outlet to OFF
		1	set Power Outlet to ON
		r	RESTART the Power Outlet(s)
		t	TOGGLE the Power Outlet(s)
<b>t<sub>1</sub></b>	delay to execute the command	1 to 255	set the delay (in sec) to execute the command
<b>t<sub>2</sub></b>	restart delay	1 to 255	set the restart delay (in sec) If t <sub>2</sub> is not specified, the used Restart Delay is the default value of the Restart Delay of the corresponding Power Outlet (see § 8.3.6)

**Examples:**

P11=1      Switch Power Outlet #1 of Power Switch #1 to On

P11=0      Switch Power Outlet #1 of Power Switch #1 to Off

P35=r      Restart Power Outlet #5 of Power Switch #3

P30=1      Switch all Power Outlets of Power Switch #3 to On

P168=t      Toggle Power Outlet #8 of Power Switch #16

P10=r,10,20      Execute the Restart Command (switch all Power Outlets of Power Switch #1 to off) after a delay of 10 sec., then switch all Power Outlets to On after a delay of 20 sec.

**Remarks:**

The Power Switch Satellite accepts lower case and upper case commands.

The Power Switch Satellite sends its reply only after having received a valid command terminated by the character [CR].

### 8.3.2 READING OUT THE POWER OUTLET STATUS

This command enables to read out the status of each Power Outlet.

**Command to be sent to the Power Switch Satellite:**

Rxy[CR]

**Reply from the Power Switch Satellite:**

Rxy=z[CR]

**Explanations:**

Parameter		Value	Function/Remark
<b>x</b>	address of the Power Switch	1 to 16	specifies the address of the Power Switch Satellite
<b>y</b>	number of the Power Outlet	1 to 8	specify the number of the Power Outlet
<b>z</b>	status	0	status of the corresponding Power Outlet is OFF
		1	status of the corresponding Power Outlet is ON

**Examples:**

R11[CR] Read Status of the Power Outlets #1 of Power Switch #1

R168[CR] Read Status of the Power Outlets #8 of Power Switch #16

**Remarks:**

The Power Switch Satellite accepts lower case and upper case commands.

The Power Switch Satellite sends its reply only after having received a valid command terminated by the character [CR].

### 8.3.3 SETTING OF THE POWER UP DELAYS

This command enables to set the Power Up Delay individually for each Power Outlet. The Delay value can be between 1 and 255 seconds (4 min 15 sec).

**Command to be sent to the Power Switch Satellite:**

TUxy=z[CR]

**Reply from the Power Switch Satellite:**

TUxy=z[CR]

**Explanations:**

Parameter		Value	Function/Remark
<b>x</b>	address of the Power Switch	1 to 16	specifies the number of the Power Switch Satellite
<b>y</b>	number of the Power Outlet	1 to 8	specifies the number of the Power Outlet
<b>z</b>	timer value	1 to 255	set the Power Up Delay (in sec)

**Examples:**

TU12=2      Set Power Up Delay of the Power Outlet #2 of Power Switch #1 to 2 sec  
 TU163=10    Set Power Up Delay of the Power Outlet #3 of Power Switch #16 to 10 sec

**Remarks:**

The Power Switch Satellite accepts lower case and upper case commands.

The Power Switch Satellite sends its reply only after having received a valid command terminated by the character [CR].

### 8.3.4 READING OUT OF THE POWER UP DELAY(S)

This command enables to read out the Power Up Delay individually for each Power Outlet.

**Command to be sent to the Power Switch Satellite:**

TUxy[CR]

**Reply from the Power Switch Satellite:**

TUxy=z[CR]

**Explanations:**

Parameter		Value	Function/Remark
<b>x</b>	address of the Power Switch	1 to 16	specifies the number of the Power Switch Satellite
<b>y</b>	number of the Power Outlet	1 to 8	specifies the number of the Power Outlet
<b>z</b>	timer value	1 to 255	shows the Power Up Delay (in sec)

**Remarks:**

The Power Switch Satellite accepts lower case and upper case commands.

The Power Switch Satellite sends its reply only after having received a valid command terminated by the character [CR].

### 8.3.5 SETTING THE RESTART DELAYS

This command enables to set the Restart Delay individually for each Power Outlet. The Delay value can be between 1 and 255 seconds (4 min 15 sec).

**Command to be sent to the Power Switch Satellite:**

TRxy=z[CR]

**Reply from the Power Switch Satellite:**

TRxy=z[CR]

**Explanations:**

Parameter		Value	Function/Remark
<b>x</b>	address of the Power Switch	1 to 16	specifies the address of the Power Switch Satellite
<b>y</b>	number of the Power Outlet	1 to 8	specifies the number of the Power Outlet
<b>z</b>	timer value	1 to 255	set the Restart Delay (in sec)

**Examples:**

TR31=17 Set Restart Delay of the Power Outlet #1 of Power Switch #3 to 17 sec

**Remarks:**

The Power Switch Satellite accepts lower case and upper case commands.

The Power Switch Satellite sends its reply only after having received a valid command terminated by the character [CR].

### 8.3.6 READING OUT OF THE RESTART DELAYS

This command enables to read out the Restart Delay individually for each Power Outlet.

**Command to be sent to the Power Switch Satellite:**

TRxy[CR]

**Reply from the Power Switch Satellite:**

TRxy=z[CR]

**Explanations:**

Parameter		Value	Function/Remark
<b>x</b>	address of the Power Switch	1 to 16	specifies the address of the Power Switch Satellite
<b>y</b>	number of the Power Outlet	1 to 8	specifies the number of the Power Outlet
<b>z</b>	timer value	1 to 255	shows the Restart Delay (in sec)

**Remarks:**

The Power Switch Satellite accepts lower case and upper case commands.

The Power Switch Satellite sends its reply only after having received a valid command terminated by the character [CR].

### 8.3.7 SETTING THE POWER UP DEFAULT STATUS

This command enables to set the Power Up Default Status individually for each Power Outlet. Settings can be "always On", "Always Off" or "Last memorized Status" before power failure.

**Command to be sent to the Power Switch Satellite:**

DPxy=z[CR]

**Reply from the Power Switch Satellite:**

DPxy=z[CR]

**Explanations:**

Parameter		Value	Function/Remark
<b>x</b>	address of the Power Switch	1 to 16	specifies the number of the Power Switch Satellite
<b>y</b>	number of the Power Outlet	1 to 8	specifies the number of the Power Outlet
<b>z</b>	default status after Power up	ON	set Power Up Default Status of the Power Outlet to ON
		OFF	set Power Up Default Status of the Power Outlet to OFF
		LAST	set Power Up Default Status of the Power Outlet to last memorized status

**Examples:**

DP37=LAST Set Power Up Default Status of the Power Outlet #7 of Power Switch #3 to last memorized status

DP165=OFF Set Power Up Default Status of the Power Outlet #5 of Power Switch #16 to OFF

**Remarks:**

The Power Switch Satellite accepts lower case and upper case commands.

The Power Switch Satellite sends its reply only after having received a valid command terminated by the character [CR].

### 8.3.8 READING OUT THE POWER UP DEFAULT STATUS

This command enables to read out the Power Up Default Status individually for each Power Outlet.

**Command to be sent to the Power Switch Satellite:**

DPxy[CR]

**Reply from the Power Switch Satellite:**

DPxy=z[CR]

**Explanations:**

Parameter		Value	Function/Remark
<b>x</b>	address of the Power Switch	1 to 16	specifies the address of the Power Switch Satellite
<b>y</b>	number of the Power Outlet	1 to 8	specifies the number of the Power Outlet
<b>z</b>	default status after Power up	ON	power up default status of the power outlet is ON
		OFF	power up default status of the power outlet is OFF
		LAST	power up default status of the power outlet is last memorized status

**Remarks:**

The Power Switch Satellite accepts lower case and upper case commands.

The Power Switch Satellite sends its reply only after having received a valid command terminated by the character [CR].

### 8.3.9 READING OUT THE SWITCHING COUNTER VALUES OF THE RELAYS

This command enables to read out the number of power up cycles of the Power Switch Satellite and the number of switching cycles (Off to On) of each power outlet.

**Command to be sent to the Power Switch Satellite:**

Cxy[CR]

**Reply from the Power Switch Satellite:**

Cxy=z[CR]

**Explanations:**

Parameter		Value	Function/Remark
<b>x</b>	address of the Power Switch	1 to 16	specifies the address of the Power Switch Satellite
<b>y</b>	counter	0	reads the number of power up cycles of the Power Switch Satellite
		1 to 8	specifies the number of the Power Outlet switching counter
<b>z</b>	counter value		shows the number of power up or switching cycles of the selected Power Outlet

**Remarks:**

The Power Switch Satellite accepts lower case and upper case commands.

The Power Switch Satellite sends its reply only after having received a valid command terminated by the character [CR].



### 8.3.10 RESETTING THE SWITCHING COUNTER VALUES OF THE RELAYS

This command enables to reset the switching counter values of the Relays.

**Command to be sent to the Power Switch Satellite:**

/RC[CR]

**Reply from the Power Switch Satellite:**

No reply

**Remarks:**

The Power Switch Satellite accepts lower case and upper case commands.

The Power Switch Satellite sends its reply only after having received a valid command terminated by the character [CR].

### 8.3.11 RESTORING TO FACTORY SETTINGS

This command enables to restore all factory settings.

**Command to be sent to the Power Switch Satellite:**

/FS[CR]

**Reply from the Power Switch Satellite:**

No reply

**Remarks:**

The Power Switch Satellite accepts lower case and upper case commands.

The Power Switch Satellite sends its reply only after having received a valid command terminated by the character [CR].

## 9. Accessories


### 9.1 Temperature sensor




### 9.2 Temperature and Humidity sensor



The figure below shows an example how to connect 2 sensors.



### 9.3 I/O extension module



# Annexes

## Ping and Scan methods

Power Switch Master has two methods to check whether an IP equipment (PC, server, router, Webcam...) is still alive:

### ADDRESS PINGING

The first method uses the well-known Ping command whereby a request is sent to a specific IP address. The Ping command, which is an echo request, enables you to determine through an ICMP protocol (Internet Control Message Protocol) if an IP device is available on the network. If the system reacts to this request, Power Switch Master knows that the TCP/IP connection is established. If the system does not react to one or several requests, Power Switch Master can automatically switch off and after a specified delay switch it again on (Reboot function).

### PORT SCANNING

The second method uses the Port Scan command to test a specific TCP/IP port. In other words, this command allows you to find out if a specific protocol is available on a server (for example HTTP, FTP, Telnet, SMTP, and POP...). Power Switch Master simply tries to connect to a specific server port. If the connection is possible, Power Switch Master knows that a server program is running there. If the connection is not possible, Power Switch Master can automatically switch off and after a specified delay switch again on the IP equipment (Reboot).

Remarks:

- The Supervision function works only if the Power Switch Master is disconnected from the LAN.
- The Ping and Scan functions can be used separately or together.
- The network route between Power Switch Master and the IP device you wish to supervise should be as direct as possible, so do not use unnecessary routers and complex wiring between them. A problem on a router or the wiring could reboot the IP device to supervise.
- Execute several Pings and/or Scans before running the Reboot function. It could be possible that the IP device doesn't respond although is still working.
- Choose a realistic supervision cycle. One second is possible, however it's not necessary to overload the network with Ping and Scan requests.

## RECOMMENDED VALUES

- |   |                 |
|---|-----------------|
| <input type="checkbox"/> Interval between Requests:                       | 10 sec or more  |
| <input type="checkbox"/> Number of unsuccessful Requests before Reboot:   | 3 or more       |
| <input type="checkbox"/> Delay before Reboot:                             | 10 sec or more  |
| <input type="checkbox"/> Delay before restarting monitoring after Reboot: | 120 sec or more |

## Commonly used ports

- |                |   |
|----------------|---|
| <b>TCP 25</b>  | This port is used to deliver e-mails over SMTP (Simple Mail Transfer Protocol).   |
| <b>TCP 80</b>  | This port is used for http connections.<br>The Power Switch Master ONLY uses Secure Port 443 (HTTPS).<br>Ensure that your Firewall / Router is configured to allow HTTPS to pass through. |
| <b>UDP 123</b> | This port is used to allow time synchronization over NTP (Network Time Protocol).   |
| <b>TCP 443</b> | This port is used to allow SSL support (Secure Socket Layer).   |
| <b>UDP 514</b> | This port is used to deliver Syslog messages.   |

## SysLog Messages: Severity Level Definitions

The Emergency level is the most severe type of message generated by Power Switch Master and the Debug severity level is the least severe one.

### **Severity Level 0, Emergency: system is unusable**

The following messages appear at severity 0:

Continuous error!

An SMTP Client could not be created

### **Severity Level 1, Alert: action must be taken immediately**

The following messages appear at severity 1:

Settings have been reinitialized through the serial connection

Power Switch Master does not respond

Satellite "number" does not respond.

Sensor "number" does not respond.

Failure on Power Input A of Master M0

Failure on Power Input B of Master M0

Failure on auxiliary Power Input of Master M0

Failure on Power Input A of Satellite (number)

Failure on Power Input B of Satellite (number)

I/O Extension Module has been disconnected

A Mail could not be sent "subject" to "name"

SMTP Client not available: a Mail could not be sent "subject" to "name"

### **Severity Level 2, Critical: critical conditions**

The following messages appear at severity 2:

"file" config corrupted : restoring default values

### **Severity Level 3, Error: error conditions, Necessary action is required.**

Power Switch Master doesn't generate Severity Level 3.

### **Severity Level 4, Warning: warning conditions, a minor condition has occurred.**

The following messages appear at severity 4:

Settings have been changed through the serial connection

Settings have been changed through the network by User "name"

### **Severity Level 5, Notice: normal but significant condition has occurred.**

The following messages appear at severity 5:

Master M0 has been connected

Satellite (number) has been connected

Sensor (number) has been connected

SSL Key has been reinitialized through the serial connection

System has been restarted through the serial connection

Power Supply A of Master restored

Power Supply B of Master restored

Auxiliary Power Supply of Master restored

Power Supply A of Satellite (number) restored

Power Supply B of Satellite (number) restored

I/O Extension Module has been connected

Rule (number) : Outlet (number) of Master has been switched ON

Rule (number) : Group (number) has been switched ON

Rule (number) : Dry Contact Output (number) has been opened

Rule (number) : Mail "subject" has been sent to "name"

**Severity Level 6, Informational: informational messages**

The following messages appear at severity 6:

System has been started

Date & Time have been synchronized to a Network Time Server

User "name" : Outlet (number) of Master M0 has been switched ON

User "name" : Group (number) has been switched ON

Dry Contact Input (number) has been open

Dry Contact Input (number) has been closed

Dry Contact Output (number) has been open


Dry Contact Output (number) has been closed

Mail "subject" has been sent to "name"

Session opened by user "name"

**Severity Level 7, Debug: debug-level messages**

Power Switch Master doesn't generate Severity Level 7.

**Pinout of the RJ11 6/6 x-Bus connector**

Pin	Signal
1	+Vout (+7V / 100mA)
2	GND
3	RS485 – B
4	RS485 – A
5	GND
6	+Vout (+7V / 100mA)

The power supply delivers a voltage of 7V  $\pm$  10% for a load of 100mA. The output is overload protected and protected against polarity inversion. The xBus connectors of both Power Switch Master and Satellite have the same features and pinout.

The symmetrical pinout of power output (+Vout) and GND prevents the risk of short circuits if the RJ11 connector is inverted.

## Technical Data

<b>Network standards</b>	IEEE 802.3, 10 / 100 BASE-T
<b>Network protocols</b>	TCP/IP, HTTP
<b>Network connection</b>	RJ-45 connector for UTP CAT5
<b>Max. network cable length</b>	100 meters (not included)
<b>Serial connection</b>	RS232, SUB-D 9 female
<b>SSL Technology</b>	Version 2 and 3
<b>Nominal input voltage</b>	230 V/50Hz
<b>Input power outlet</b>	IEC-320
<b>Output voltage</b>	230 V/50Hz
<b>Output power outlet</b>	IEC-320
<b>Maximum total current</b>	2 x 10 A
<b>LEDs</b>	1 for Power Supply A 1 for Power Supply B 8 for the Power Outlets status 1 for System Status 4 for Dry Contacts Output Status 1 for Network traffic 1 for Network Speed 10 / 100 Mbits/s
<b>Operating temperature</b>	0°C to +40°C
<b>Operating humidity</b>	10% to 80%
<b>Dimensions (LxDxH)</b>	437 x 107 x 42 mm
<b>Weight</b>	2 kg
<b>Approvals</b>	CE, EN55022 & EN55024

